NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

WATER WELL REPORT E I VE D STATE OF OREGON STATE Well No.

State Permit No. 63/2W-6
DEPT. **JUN 8** 1976 STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion. (Please type or print) (Do not write above WATER RESOURCES DEPT. of well completion. SALEM, OREGON

(1) OWNER:	(10) LOCATION OF WELL:		
Name Robert Zielinski Sr.	County Marion Driller's well nu	ımber 1953	
Address Rt. 1 Box 59 Gervais OR 97026	34 34 Section 6 T. 65	R. 2W	W.M.
	Bearing and distance from section or subdivision	on corner	
(2) TYPE OF WORK (check):			
New Well 🕱 Deepening 🗌 Reconditioning 🖺 Abandon 🗎			
f abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	ell.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found	61	ft.
Rotary Driven Domestic Industrial Municipal		surface. Date 5/	
Cable of Jetted []			44/90
Dug	Artesian pressure Ibs. per squar	e inch. Date	
CASING INSTALLED: Threaded Welded	(12) WELL LOG: Diameter of well b		0
10" Diam. from top ft. to 140 ft. Gage 250			
" Diam. from ft. to ft. Gage		1-407	ft.
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size a and show thickness and nature of each stratur		
PENDEOD A DVOVO	with at least one entry for each change of format		
PERFORATIONS: Perforated? M Yes \(\square\) No.	position of Static Water Level and indicate prin	cipai water-oearin	g strata.
Type of perforator used Mills Knife	MATERIAL	From To	SWL
Size of perforations 7/16 in. by 2 3/4 in.	Brown Topsoil	0 2	
670 perforations from 66 ft. to 117 ft.	Brown Silty Clay	2 33	
perforations fromft. toft.	Blue Silty Clay	33 62	
perforations fromft, toft.	Black Sand And Gravel	62 73	
(7) SCREENS: Well screen installed? Yes No	Brown cemented Sand And Grave	73 117	
	Gray silty Clay	117 150	
Manufacturer's Name			
Diam. Slot size Set from ft. to ft.			
Diam. Slot size Set from ft. to ft.			
(8) WELL TESTS: Drawdown is amount water level is lowered below static level			
Was a pump test made? ₩ Yes □ No If yes, by whom? driller			
Yist: 250 gal./min. with 5 ft. drawdown after 1 hrs.			
400 " 15 " 1 "			
" 600 " 23 " 3 "			
	:		
Bailer test gal./min. with ft. drawdown after hrs.	ng and a second		
Artesian flow g.p.m.	5/4/76		
perature of water 53 Depth artesian flow encountered ft.	Work started 5778778 19 Complete	ed 5/20/76	19
(9) CONSTRUCTION:	Date well drilling machine moved off of well	5/21/76	,19 t \$0
Well seal-Material used Portland Cement	Drilling Machine Operator's Certification:		* *
Well sealed from land surface to $\frac{20}{1000}$	This well was constructed under my Materials used and information reported	direct super	višion.
Diameter of well bore to bottom of sealin.	best knowledge and belief	above are true	w my
Diameter of well bore below seal in.	[Signed] Dallas & Beis	Date 5/21/76	. 19
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No		
Number of sacks of bentonite used in well seal sacks	Drilling Machine Operator's License No	112	
Brand name of bentonite	Water Well Contractor's Certification:		
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdi	ction and this m	anort is
of waterlbs./100 gals.	true to the best of my knowledge and beli	ief.	-Port 18
Was a drive shoe used? ■ Yes □ No Plus Size: location ft.	Name Willamette Drilling Co.	****************	
Did any strata contain unusable water? Yes No	(Person, firm or corporation)	(Type or prin	-
Type of water? depth of strata	Address 1450 Barnick Rd. NE Sale	am, Bragon) 7303.
Method of sealing strata off	[Signed] Dallas & Beers		
Was well gravel packed? Tes No Size of gravel:	(Water Well Contra	The state of the s	
Gravel placed fromft, toft.	Contractor's License No. 561 Date 5	/21/76	., 19