

MAR 3 8 33

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED APR 22 1963

WATER WELL REPORT

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

STATE ENGINEER SALEM OREGON

STATE OF OREGON (Please type or print)

State Well No. 6/24-6 dab State Permit No. G 5090

(1) OWNER:

Name HOMER ZIELINSKI Address RT. 1 BOX 69 GERVAIS, OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number 819 Section 6 T. 6S R. 2 W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

8" Diam. from TOP ft. to 133 1/2 ft. Gage Threaded [] Welded [X]

(7) PERFORATIONS:

Type of perforator used MILLS Perforated? [X] Yes [] No Size of perforations 352 in. by 95 in. 130 ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal-Material used in seal PUDDLE CLAY Depth of seal 20 ft. Was a packer used? Diameter of well bore to bottom of seal in. Were any loose strata cemented off? [] Yes [] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 20 ft. below land surface Date Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [] No If yes, by whom? DRILLER Yield: 400 gal./min. with 70 ft. drawdown after 5 hrs. " 370 " 69 " 5 " " 330 " 62 " 5 " 270 gal./min. with 51 ft. drawdown after 5 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well below casing Depth drilled 133 1/2 ft. Depth of completed well 133 1/2 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include TOP SOIL & RED CLAY, BLUE CLAY, BLACK CLAY, BLACK SAND & CLAY, SAND & BIG GRAVEL, SMALL GRAVEL & SAND, BLACK SANDY CLAY, SAND & GRAVEL.

Work started APRIL 6 1963 Completed APR. 11 1963 Date well drilling machine moved off of well 19

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO (Person, firm or corporation) (Type or print) Address RT. 2 BOX 276 SALEM, OREGON Drilling Machine Operator's License No. 2 141 [Signed] Emil O. Beier (Water Well Contractor) Contractor's License No. 2 Date APR. 11 1963