

MARION... 3835

RECEIVED

WATER WELL REPORT G-4264

State Well No. 6/2W-6M

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE OF OREGON

G-4743 G-3822 G2260

State Permit No. G-2076

(1) OWNER: MR TED V, BELL Name Address RT. 1 BOX 75 GERVAIS OREGON

(2) LOCATION OF WELL: County MARION Owner's number, if any - 1/4 Section 6 T. 6 R. 2W W.M. Bearing and distance from section or subdivision corner & S 6 Twp 6 RANGE 2W MARION COUNTY OREGON

(3) TYPE OF WORK (check): New Well [x] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check): Domestic [] Industrial [] Municipal [] Irrigation [x] Test Well [] Other [] (5) TYPE OF WELL: Rotary [] Cable [x] Dug [] Driven [] Jetted [] Bored []

(6) CASING INSTALLED: Threaded [] Welded [x] 10" Diam. from TOP ft. to 142 ft. Gage

(7) PERFORATIONS: Perforated? [x] Yes [] No Type of perforator used MILLS SIZE of perforations 400 in. by 2" in. 98 ft. to 140 ft.

(8) SCREENS: Well screen installed [] Yes [x] No Manufacturer's Name Type Model No. Slot size Set from ft. to

(9) CONSTRUCTION: Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to 20 ft. Was a surface seal provided? [x] Yes [] No To what depth? 20 ft. Material used in seal- PUDDLE CLAY Did any strata contain unusable water? [] Yes [] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS: Static level 35 ft. below land surface Date Artesian pressure lbs. per square inch Date Log Accepted by: [Signature] Date 3-19, 1962 [Signed] (Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [] No If yes, by whom? DRILLER Yield: 675 gal./min. with 47 ft. drawdown after 7 hrs. " 650 GAL " 43 " 7 " " 600 " 40 " 7 " Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG: Diameter of well 10 inches. Depth drilled 142 ft. Depth of completed well 142 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include 500 GAL PER M AT 34 FT., 400 GAL PER M AT 31 FT., 300 GAL PER M AT 20, TOP DIRT, YELLOW CLAY, SILTY YELLOW CLAY, STICKY YELLOW CLAY, SANDY GRAY SHALE, SANDY BLACK SHALE, BLACK SAND, BLACK SAND & GRAVEL, BROWN SAND & GRAVEL, BLUE SHALE.

Work started FEB 27 19 62 Completed MAR 16 19 62

(13) PUMP: Manufacturer's Name Type: H.P.

Well Driller's Statement: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO (Person, firm, or corporation) (Type or print) Address RT. 2 BOX 276 SALEM, OREGON Driller's well number 717 [Signed] [Signature] (Well Driller) License No. 8 Date MARCH 16 1962