

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED
MAY 6 1968
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

3844
MARI....

State Well No. 6/2w-7

State Permit No.

(1) OWNER:

Name FRED ZIELINSKI
Address 9995 RIVER RD. N.E. SALEM, ORE.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
10" Diam. from 0 ft. to 147' ft. Gage 1/4"
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used MILLS.
Size of perforations 3/8 in. by 2 1/2 in.
140 perforations from 88' ft. to 96' ft.
590 perforations from 103' ft. to 138' ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 25' 5" ft. below land surface Date 4-17-68
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? STOTTLE & SUPPLY
530 gal./min. with 396' ft. drawdown after 1/2 hrs.
660 " 49' " 1/2 "
800 " 58' " 1/2 "
920 " 70' " 1/2 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 51° Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used BENTONITE
Depth of seal 70' ft.
Diameter of well bore to bottom of seal 14" in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? SANDY depth of strata 51' to 66'
Method of sealing strata off CASED.
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County MARION Driller's well number
1/4 Section 7 T. 6 R. 2W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 10"

Depth drilled 147' ft. Depth of completed well 147' ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOPSOIL	0	2	
CLAY YELLOW	2	3	
CLAY GRAY	3	6	
CLAY YELLOW	6	21	
CLAY BLUE SILTY	21	51	
SAND - MUDDY BLACK	51	66	
CLAY BLUE STICKY	66	72	
CLAYSTONE BLUE FIRM	72	79	
CONGLOMERATE	79	86	
GRAVEL 2"	86	96	
CLAYSTONE GRAY-FIRM	96	103	
CONGLOMERATE	103	106	
GRAVEL + SAND 2"	106	107 1/2	
CONGLOMERATE	107 1/2	121 1/2	
GRAVEL - 3"	121 1/2	124	
CONGLOMERATE	124	138	
CLAY BLUE - STICKY	138	147	

Work started 4-12 1968 Completed 4-17- 1968

Date well drilling machine moved off of well 4-17- 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] B. F. Sneed Date 4-17, 1968
(Drilling Machine Operator)

Drilling Machine Operator's License No. 187

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. A. SNEED & SONS
(Person, firm or corporation) (Type or print)

Address 3910 SILVERTON RD SALEM, ORE.

[Signed] B. F. Sneed
(Water Well Contractor)

Contractor's License No. 6 Date 4-17- 1968