

MARION 3846

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the  
STATE ENGINEER, SALEM 10, OREGON  
within 30 days from the date  
of well completion.

WATER WELL REPORT

STATE OF OREGON  
(Please type or print)

State Well No. 6/3w-7

State Permit No.

(1) OWNER:

Name FRED ZIELINSKI  
Address RT. I BOX 24  
BROOKS, OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number 829  
1/4 1/4 Section 7-12 T. 6S R. 2W& 3W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Deepening  Reconditioning  Abandon   
 abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
10" Diam. from TOP ft. to 150 ft. Gage  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used MILLS  
Size of perforations in. by in.  
330 perforations from 115 ft. to 146 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name  
Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal  
Depth of seal ft. Was a packer used?  
Diameter of well bore to bottom of seal in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? Depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 20 ft. below land surface Date  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level.  
Was a pump test made?  Yes  No If yes, by whom? DRILLER  
Yield: 350 gal./min. with 51 ft. drawdown after 9 hrs.  
" 400 " 73 " 9 "  
" 450 " 87 " 9 "  
Ballor test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing  
Depth drilled 155 ft. Depth of completed well 155 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
PIPE SET IN OLD WELL	0	38
THIS WAS AN OLD TILE WELL		
DRILLED & CLEANED OUT FROM	38	62
SAND	62	80
CLAY	80	95
GRAVEL	95	100
CLAY	100	115
GRAVEL	115	146
CLAY	146	155

REST OF PUMP TEST

475 G.P.M. 130 FT DD AFTER 9 HRS

Work started MAY 17 1963 Completed MAY 28 1963  
Date well drilling machine moved off of well 19

(13) PUMP:

Manufacturer's Name  
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO  
(Person, firm or corporation) (Type or print)

Address RT. 2 BOX 276 SALEM, OREGON

Drilling Machine Operator's License No. 141

[Signed] Emil O. Beier  
(Water Well Contractor)

Contractor's License No. 2 Date MAY 28 1963