

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

**WATER WELL REPORT**

**RECEIVED**

STATE OF OREGON

OCT 4 1973

State Well No.

65/2w-9

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

(Please type or print) STATE ENGINEER

State Permit No.

(Do not write above this line) SALEM, OREGON

**(1) OWNER:**

Name MELVIN BRADLEY  
Address 5693 Tumbleweed circle  
Brooks, Oregon

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dig  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

10" Diam. from 0 ft. to 125 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

**(6) PERFORATIONS:**

Perforated?  Yes  No.

Type of perforator used Touch  
Size of perforations in. by in.  
150 perforations from 10.2 ft. to 12.2 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? Stettin Pump  
: 200 gal./min. with 38 ft. drawdown after 24 hrs.

Baller test gal./min. with ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

**(9) CONSTRUCTION:**

Well seal—Material used Pum Pad cement grout  
Well sealed from land surface to 41 ft.  
Diameter of well bore to bottom of seal 14 in.  
Diameter of well bore below seal 10 in.  
Number of sacks of cement used in well seal 29 sacks  
Number of sacks of bentonite used in well seal sacks  
Brand name of bentonite  
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.  
Was a drive shoe used?  Yes  No Plus Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

**(10) LOCATION OF WELL:**

County MARION Driller's well number  
1/4 1/4 Section 9 T. 6S R. 2W W.M.  
Bearing and distance from section or subdivision corner

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 39 ft.  
Static level 33 ft. below land surface. Date 9/18/73  
Artesian pressure lbs. per square inch. Date

**(12) WELL LOG:**

Diameter of well below casing 10"

Depth drilled 135 ft. Depth of completed well 125 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
top soil	0'	3'	
brown clay	3	16	
brown sandy clay	16	32	
gray clay	32	38	
gray sand-dark	38	47	
blue clay	47	73	
yellow clay	73	78	
blue sandy clay	78	87	
medium gravel	87	123	
blue clay	123	135	

Work started 9/18/73 19 Completed 9/18/73 19

Date well drilling machine moved off of well 9/18/73 19

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] George V. Wood Date 9/24/73 19  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 510

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name CORVALLIS DRILLING CO INC  
(Person, firm or corporation) (Type or print)

Address 3440 sw 3rd; Corvallis, Oregon

[Signed] Clarence A. Kinnaman  
(Water Well Contractor)

Contractor's License No. 560 Date 9/24/73 19