

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

MARION... 8896

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date of well completion.

RECEIVED  
APR 14 1968

STATE OF OREGON

(Please type or print)  
(Do not write above this line)

State Well No. 6/2W-96 1/2  
State Permit No.

(1) OWNER:

Name EDDIE CAIN  
Address 10020 PORTLAND RD.  
BROOKS, OREGON 97305

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) CASING INSTALLED:

Threaded  Welded   
10" Diam. from 0 ft. to 200 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated?  Yes  No.

Type of perforator used WELLS PERFORATOR  
Size of perforations 3/8 in. by 2 in.  
160 perforations from 95 ft. to 100 ft.  
390 perforations from 110 ft. to 120 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
Type \_\_\_\_\_ Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WATER LEVEL: Completed well.

Static level 15 ft. below land surface Date APRIL 10 1968  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? STETTLER'S  
d: 600 gal./min. with 60 ft. drawdown after 3 hrs.  
" 750 " 85 " 3 "  
" " " " "  
Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water 54° Was a chemical analysis made?  Yes  No

(10) CONSTRUCTION:

Well seal—Material used PUDDLE CLAY  
Depth of seal 25 FOOT ft.  
Diameter of well bore to bottom of seal 12 in.  
Were any loose strata cemented on?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(11) LOCATION OF WELL:

County MARION Driller's well number \_\_\_\_\_  
1/4 1/4 Section 9 T. 6 S. R. 2 WEST W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(12) WELL LOG:

Diameter of well below casing \_\_\_\_\_

Depth drilled 200 ft. Depth of completed well 200 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOPOSOIL	0	1	
BROWN CLAY	1	30	
BROWN SILKY SAND	30	35	
BLUE CLAY	35	55	
GREY SAND	55	65	
BLUE CLAY	65	75	
BLACK SAND	75	90	
SAND & GRAVEL	90	100	
BLUE CLAY	100	110	
GRAVEL	110	130	
BLUE CLAY	130	175	
BLACK SAND	175	195	
TIGHT GRAVEL	195	200	

Work started 3/22 19 68 Completed 4/10 19 68  
Date well drilling machine moved off of well 4/3 19 68

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] J. F. Terrell Date April 10, 1968  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 179

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. F. TERRELL WELL DRILLING  
(Person, firm or corporation) (Type or print)

Address Rt. # 1, BOX 57, GERVAIS, OREGON

[Signed] Max. Zona G. Terrell  
(Water Well Contractor)

Contractor's License No. 460 Date April 10, 1968