

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
MAY 9 1967
STATE ENGINEER
SALEM, OREGON

MAY 1967
3898
STATE OF OREGON
Please type or print
G-3935

State Well No. 6/2w-9H
State Permit No. _____

(1) OWNER:
Name FRANK PETZEL
Address 7198 RIVER RD. N.E.
SALEM, OREGON 97303

(2) LOCATION OF WELL:
County MARION Driller's well number I209
1/4 Section 9 T. 6 S R. 2 W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL: Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED: Threaded Welded
" Diam. from _____ ft. to _____ ft. Gage _____
10 " Diam. from TOP ft. to 220 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used MILLS
Size of perforations 2 in. by 3/8 in.
70 perforations from 130 ft. to 135 ft.
120 perforations from 165 ft. to 175 ft.
230 perforations from 200 ft. to 220 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Well seal—Material used in seal CEMENT & PUDDLE CLAY
Depth of seal 20 ft. Was a packer used? _____
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 30 ft. below land surface Date 4/27/ 67
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? DRILLER
Yield: 700 gal./min. with 15 ft. drawdown after 10 hrs.
" 600 " " 131 " " 10 "
" 500 " " 10 " " 10 "
~~Yield:~~ 400 gal./min. with 8 ft. drawdown after 10 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing _____
Depth drilled 220 ft. Depth of completed well 220 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	3
YELLOW CLAY	3	20
YELLOW SANDY CLAY	20	45
BLUE SHALE	45	75
BLACK SAND	75	90
GRAYISH BLUE SHALE	90	105
BROWN SAND	105	120
BROWN SAND & SOME SMALL GRAVEL	120	130
SAND GRAVEL & MUD	130	135
BROWN SHALE	135	145
BLACK SANDY SHALE	145	150
STICKY SHALE BLACK	150	160
BLACK SAND SMALL GRAVEL & MUD	160	170
BLACK SAND & SMALL GRAVEL	170	174
BLUE SHALE	174	177
BLACK SAND SCATTERED GRAVEL	177	197
BROWN & BLACKSAND & PEA GRAVEL & LARGER GRAVEL	197	220

Work started MAR. 30 1967 Completed APRIL 27 1967
Date well drilling machine moved off of well APRIL 27 1967

(13) PUMP:
Manufacturer's Name _____
Type: _____ H.P. _____
Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME WILLAMETTE DRILLING CO. 97303
(Person, firm or corporation) (Type or print)
Address RT. 2 BOX 276 SALEM, OREGON
Drilling Machine Operator's License No. 74
[Signed] Emil O. Beier
(Water Well Contractor)
Contractor's License No. 2 Date APRIL 27 1967