

The original and first copy of this report are to be filed with the

RECEIVED

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 65/2W-11

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion

STATE ENGINEER SALEM, OREGON

(Do not write above this line)

66919

(1) OWNER:

Name Dennis Mc Cloughy Address 8479 Roanoke St. Salem, Ore.

(2) TYPE OF WORK (check):

New Well [x] Deepening [ ] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [x] Jetted [ ] Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [x] Test Well [ ] Other [ ]

CASING INSTALLED:

10" Diam. from +2 ft. to 143 ft. Gage .250

PERFORATIONS:

Type of perforator used Mill Size of perforations 3/8 in. by 2 1/2 in. 1.89 perforations from 117 ft. to 127 ft.

(7) SCREENS:

Well screen installed? [ ] Yes [x] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [ ] Yes [x] No Yield: No test

(9) CONSTRUCTION:

Well seal—Material used Bentonite Well sealed from land surface to 30 ft. Diameter of well bore to bottom of seal 14 in.

(10) LOCATION OF WELL:

County Marion Driller's well number 1/4 Section 11 T. 6S R. 2W W.M. Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 10 ft. Static level 11 ft. below land surface. Date 6-19-74

(12) WELL LOG:

Diameter of well below casing 10" Depth drilled 143 ft. Depth of completed well 143 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, From, To, SWL. Rows include: Brown Clay, Brown Sandy Clay, Brown Clay, Brown Sand & Clay, Brown Clay, Brown Sand, Grey Clay, Black Sand, Small med Gravel (Sand), Grey Clay, Small to med Gravel, Grey Clay, Cemented Gravel (with layers of loose Gravel).

Work started 6-11-74 Completed 6-19 1974 Date well drilling machine moved off of well 6-19 1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Norman Stewell Date 6-19, 1974 (Drilling Machine Operator)

Drilling Machine Operator's License No. 455

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name ROBINSON'S EOLA WELL DRILLING (Person, firm or contractor) (Type or print)

Address 4540 DALLAS RD., N.W. SALEM, OREGON 97304

[Signed] George H. Robinson (Water Well Contractor)

Contractor's License No. 103 Date 6-19, 1974