

MAR 31 1966 3949

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON (Please type or print)

State Well No. 6/2w-11 State Permit No.

(1) OWNER:

Name THOMAS HENNY Address RT. I BOX I59B BROOKS, OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number I129 Section II T. 6S R. 2W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [X] Test Well [ ] Other [ ] Rotary [ ] Driven [ ] Cable [X] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED:

8" Diam. from TOP ft. to 125 ft. Gage 250 160 ft. Gage

(7) PERFORATIONS:

Perforated? [X] Yes [ ] No Type of perforator used MILLS Size of perforations 2 in. by 3/8 in. 96 perforations from 127 ft. to 135 ft. 40 perforations from 154 ft. to 159 ft.

(8) SCREENS:

Well screen installed? [ ] Yes [X] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUDDLE CLAY Depth of seal 20 ft. Was a packer used? Diameter of well bore to bottom of seal 10 in. Were any loose strata cemented off? [ ] Yes [ ] No Depth Was a drive shoe used? [X] Yes [ ] No Was well gravel packed? [ ] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [ ] Yes [ ] No Type of water? dept of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 25 ft. below land surface Date 4/14/66 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [ ] No If yes, by whom? DRILLER Yield: 330 gal./min. with 127 ft. drawdown after 10 hrs. 300 " 106 " 10 " 275 " 102 " 10 " 250 gal./min. with 92 ft. drawdown after 10 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [ ] Yes [ ] No

(12) WELL LOG:

Diameter of well below casing Depth drilled 160 ft. Depth of completed well 160 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include TOP SOIL, BROWN CLAY, BROWN SILTY SAND, BROWN SAND, BROWN SAND WITH CLAY, GRAY CLAY, BROWN SAND, GRAY CLAY, BLACK SAND & WOOD, BROWN SAND & WOOD & GRAVEL, GRAY CLAY & BLACK SAND, GRAVEL, BLACK SAND WITH WOOD, BLACK SAND & GRAVEL & CLAY.

Work started APRIL 1 1966 Completed APRIL 14 1966 Date well drilling machine moved off of well APRIL 14 1966

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO (Person, firm or corporation) (Type or print) Address RT. 2 BOX 276 SALEM, OREGON

Drilling Machine Operator's License No. 151

[Signed] Emil O. Baier (Water Well Contractor)

Contractor's License No. 2 Date APRIL 14 1966