NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

# WATER WELL REPORT
## STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. .....
State Permit No. G-6401

**(1) OWNER:**
Name Ray O. Fisher
Address 7991 Stratford Dr. Salem.

**(2) TYPE OF WORK (check):**
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

**(4) PROPOSED USE (check):**
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☑ Test Well ☐ Other ☐

**CASING INSTALLED:** Threaded ☐ Welded ☑
10" Diam. from +1 ft. to 156 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

**PERFORATIONS:** Perforated? ☑ Yes ☐ No.
Type of perforator used Mills
Size of perforations 3/8 in. by 2½ in.
228 perforations from 108 ft. to 117 ft.
372 perforations from 136 ft. to 151 ft.
perforations from ft. to ft.

**(7) SCREENS:** Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

**(8) WELL TESTS:** Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
" " "
Bailer test 50 gal./min. with 0 ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

**(9) CONSTRUCTION:**
Well seal—Material used Bentonite
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 14 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal 21 sacks
Brand name of bentonite National
Number of pounds of bentonite per 100 gallons of water 20 lbs./100 gals.
Was a drive shoe used? ☑ Yes ☐ No Plug Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

**(10) LOCATION OF WELL:**
County Marion Driller's well number
¼ ¼ Section 11 T. 4S R. 2W W.M.
Bearing and distance from section or subdivision corner

**(11) WATER LEVEL: Completed well.**
Depth at which water was first found 40 ft.
Static level 9 ft. below land surface. Date 5-31-74
Artesian pressure lbs. per square inch. Date

**(12) WELL LOG:** Diameter of well below casing 10
Depth drilled 156 ft. Depth of completed well 156 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

| MATERIAL | From | To | SWL |
|---|---|---|---|
| Brown Clay | 0 | 30 | |
| Brown Sandy Clay | 30 | 52 | |
| Grey Clay | 52 | 66 | |
| Sand & Gravel | 66 | 83 | |
| Packed Sand | 83 | 85 | |
| Grey Clay | 85 | 95 | |
| Soft (Rotten Wood) | 95 | 101 | |
| Gravel | 101 | 108 | |
| Rock Sand | 108 | 123 | |
| Grey Clay | 123 | 132 | |
| Gravel | 132 | 141 | |
| Cement Gravel | 141 | 153 | |
| With Layers of Rock | | | |
| Grey Clay | 153 | 156 | |

Work started 3-11 19 74 Completed 5-20 19 74
Date well drilling machine moved off of well 5-31 19 74

**Drilling Machine Operator's Certification:**
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] [illegible] Date 5-31, 19 74
(Drilling Machine Operator)
Drilling Machine Operator's License No. 455

**Water Well Contractor's Certification:**
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name ROBINSON'S EOLA WELL DRILLING
(Person, firm, or corporation) (Type or print)
Address 4510 DALLAS RD., N. W.
SALEM, OREGON 97304
[Signed]
(Water Well Contractor)
Contractor's License No. Date 19

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119