

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

3953
MARI.....

WATER WELL REPORT

STATE OF OREGON

(Please type or print)
(Do not write above this line)

RECEIVED

MAY 2 1968

STATE ENGINEER
SALEM OREGON
G-4439

State Well No. 6/2w-11 R
State Permit No.

(1) OWNER:

Name Clyde Reed
Address 9783 86th Ave. Salem, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
12" Diam. from top ft. to 120 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used Mills
Size of perforations $\frac{1}{8}$ in. by $2\frac{1}{8}$ in.
168 perforations from 106 ft. to 119 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 1 ft. below land surface Date 4-20-68
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Driller
Wield: 600 gal./min. with 39 ft. drawdown after 6 hrs.
500 " " 33 " " 6 "
400 " " 24 " " 6 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 55 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Drill cuttings Puddle clay
Depth of seal 20 ft.
Diameter of well bore to bottom of seal 14 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Marion Driller's well number 1301
 $\frac{1}{4}$ $\frac{1}{4}$ Section 11 T. 6S R. 2W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing

Depth drilled 120 ft. Depth of completed well 120 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top Soil	0	2	
Gray Clay	2	60	
Black sandy shale	60	78	
Black Sand	78	85	
Black sand, & Gravel	85	90	
Black sandy shale	90	102	
Black sand & gravel	102	119	
Gray Clay	119	120	1

Work started 4-15-68 19 Completed 4-20-68 19
Date well drilling machine moved off of well 4-20-68 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Kenetha W. Wiggins Date 4-22-68 19
(Drilling Machine Operator)

Drilling Machine Operator's License No. 474

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING COMPANY
(Person, firm or corporation) (Type or print)

Address 7641 35th Ave. NE Salem, Oregon.

[Signed] Emil D. Beebe
(Water Well Contractor)

Contractor's License No. 2 Date 4-22-68, 19