

The original and first copy of this report are to be filed with the

RECEIVED MAR 13 1975 WATER WELL REPORT STATE OF OREGON APR 12 1974

RECEIVED

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON (Please type or print)

FEB 13 1975

State Well No. 65/2W-12dd

STATE ENGINEER SALEM, OREGON State Permit No. G 6856

(1) OWNER:

Name Joe P. P... Address 9914 86th Ave Salem 97305

(2) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [x] Test Well [] Other []

(10) LOCATION OF WELL:

County Marion Driller's well number 1/4 1/4 Section 12 T. 6S R. 2W W.M.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 25 ft. Static level +2 ft. below land surface. Date 3-5-74

(12) WELL LOG:

Diameter of well below casing 10 ft. Depth drilled 183 ft. Depth of completed well 183 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, From, To, SWL. Rows include Brown Clay, Brown Sandy Clay, Brown Sand, Clay & Gravel, Brown Sand Some gravel, Brown Clay, Gray Clay, Black Sand w/ Rotten Wood, Cemented Gravel, Small & med Gravel, Gray Clay, Small to Large Gravel, Cemented Gravel, Gravel, Cemented Gravel, Gravel, Brown Sand, Cemented Gravel.

CASING INSTALLED:

10" Diam. from +1 ft. to 183 ft. Gage 250

PERFORATIONS:

Type of perforator used Mills Size of perforations 3/8 in. by 2 1/2 in. 648 perforations from 120 ft. to 160 ft.

(7) SCREENS:

Well screen installed? [x] Yes [] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level. Was a pump test made? [] Yes [] No Yield: 200 gal./min. with 10.3 ft. drawdown after 3 hrs. Test to be made later.

(9) CONSTRUCTION:

Well seal-Material used Bentonite Well sealed from land surface to 18 ft. Diameter of well bore to bottom of seal 14 in. Diameter of well bore below seal 10 in. Number of sacks of cement used in well seal sacks Number of sacks of bentonite used in well seal 2 sacks Brand name of bentonite National Number of pounds of bentonite per 100 gallons of water 30 lbs./100 gals. Was a drive shoe used? [x] Yes [] No Plugs Size: location ft. Did any strata contain unusable water? [] Yes [x] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft.

Work started 2-5 19 74 Completed 3-4 19 74 Date well drilling machine moved off of well 3-5 19 74

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Norman O. L... Date 3-5 19 74 (Drilling Machine Operator)

Drilling Machine Operator's License No. 455.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name ROBINSON'S EOLA WELL DRILLING (Person, 4510 DALLAS RD., N. W. (Type or print)

Address SALEM, OREGON 97304

[Signed] George H. Robinson (Water Well Contractor)

Contractor's License No. 13 Date 3-5 19 74