

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

MARI 3959 RECEIVED WATER WELL REPORT

65/2W-12 13

STATE ENGINEER, SALEM, OREGON 97810 within 30 days from the date of well completion.

STATE OF OREGON (Please type or print)

FEB 5 - 1976

State Well No.

NENW

(Do not write above this line)

WATER RESOURCES DEPT. SALEM, OREGON

State Permit No.

(1) OWNER:

Name W. C. Cox Address 9581 Howell Prairie Rd. N.E. Salem, Oregon 97303

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [X] Jetted [ ] Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [X] Test Well [ ] Other [ ]

(5) CASING INSTALLED:

12" Diam. from 1+ ft. to 170 ft. Gage .250

(6) PERFORATIONS:

Type of perforator used Mills knife Size of perforations 3/8 in. by 3 in. 1016 perforations from 100 ft. to 165 ft.

(7) SCREENS:

Well screen installed? [ ] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [ ] No If yes, by whom? Driller Yield: 1050 gal./min. with 25 ft. drawdown after 4 hrs.

(9) CONSTRUCTION:

Well seal—Material used Cement Grout, Bentonite Well sealed from land surface to 50 ft. puddled clay Diameter of well bore to bottom of seal 24" 1/2 in. Diameter of well bore below seal 12 in. Number of sacks of cement used in well seal 75 sacks Number of sacks of bentonite used in well seal 10 x sacks Brand name of bentonite National & International Number of pounds of bentonite per 100 gallons of water 120 lbs./100 gals. Was a drive shoe used? [X] Yes [ ] No Plugs Size: location ft. Did any strata contain unusable water? [ ] Yes [X] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [ ] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number S.W. 1/4 S.E. 1/4 Section 12 T. 6 S R. 2 W W.M. Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 52 ft. Static level 12 ft. below land surface. Date 10/1/75 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 12 Depth drilled 170 ft. Depth of completed well 170 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include: Top soil brown, Sand & clay brown, Medium gravel & sand, Sand & clay grey, Coarse gravel & sand, Clay Blue, Med-conglomerate Grey, Medium gravel brown, Med. Conglom. grey hard, Med. Conglom. brown hard, Fine Conglom. grey hard.

Work started 6/10/75 19 Completed 10/1/75 19 Date well drilling machine moved off of well 10/2/75 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Burr Ramba Date 10-20-75 (Drilling Machine Operator)

Drilling Machine Operator's License No. 895

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name R. Stadeli & Sons, Inc. (Person, firm or corporation) (Type or print) 97381

Address 11364 Evergreen Rd. N.E. Silverton

[Signed] Paul R. Stadeli (Water Well Contractor)

Contractor's License No. 296 Date 10-18, 1975