NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

NOV 29 19 STATE OF OREGON OCT 24 1972 State Well No. STATE ENGINEER, SALEM, OREGON 97310

(Please type or print) ATE ENGINEER
within 30 days from the date ATE ENGINEER
of well completion.

SALEM. OREGON

SALEM. OREGON (10) LOCATION OF WELL: (1) OWNER: Driller's well number 1679 County Marion Name Pete Lelack Address 9593 86th Ave. NE Rt. 6 14 14 Section 13 T. 6S R. 2W Brooks, Oregon 97305 Bearing and distance from section or subdivision corner (2) TYPE OF WORK (check): Reconditioning [Abandon [New Well [Deepening X If abandonment, describe material and procedure in Item 12. (11) WATER LEVEL: Completed well. (3) TYPE OF WELL: (4) PROPOSED USE (check): Depth at which water was first found Rotary Driven | Static level ft. below land surface. Date 10-12-72 Domestic | Industrial | Municipal | Cable Jetted | Irrigation 🔽 Test Well 🗌 Other Dug Bored | Artesian pressure lbs. per square inch. Date 5) CASING INSTALLED: Threaded [Welded 2 (12) WELL LOG: Diameter of well below casing . 10 " Diam, from 109 ft. to 134 ft. Gage 250 Depth drilled 25 ft. Depth of completed well " Diam. from _____ft. to _____ft. Gage ____ Formation: Describe color, texture, grain size and structure of materials; "Diam. from ft. to ft. Gage and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.) PERFORATIONS: Perforated? X Yes

No. MATERIAL From SWL. Type of perforator used Mills in. by 3/8 in. Size of perforations Black sand and gravel with 450 perforations from 134 ft. to 95 ft. increasing cementation 109 134 perforations from _____ft. to _____ft. perforations from ______ft. to _____ft. (7) SCREENS: Well screen installed? 🗌 Yes 🕱 No Manufacturer's Name Diam. Slot size Set from ft. to ft. Diam. Slot size Set from ___ ft. to .____ ft. Drawdown is amount water level is lowered below static level (8) WELL TESTS: Was a pump test made? ₩ Yes □ No If yes, by whom? Driller gal./min. with 45 ft. drawdown after 6 hrs. same 500 70 600 same " gal./min. with 84 ft. drawdown aftersame hrs. Bailer test700 Artesian flow Depth artesian flow encountered _____ ft. nperature of water Work started 10-2-72 Completed 10-12-72 19 Date well drilling machine moved off of well 10-12-72 (9) CONSTRUCTION: Drilling Machine Operator's Certification: Well seal-Material used ... Cement and Puddle Clay This well was constructed under my direct supervision. Materials used and information reported above are true to my Diameter of well bore to bottom of seal _____in. (Drilling Machine Operator) Diameter of well bore below seal _____________in. Date 10-13-7219 Number of sacks of cement used in well seal6....... sacks Number of sacks of bentonite used in well seal Brand name of bentonite Water Well Contractor's Certification: Number of pounds of bentonite per 100 gallons This well was drilled under my jurisdiction and this report is _____lbs./100 gals. true to the best of my knowledge and belief. Name WILLAMETTE DRILLING COMPANY
(Person, firm or corporation) (Type or print) Was a drive shoe used?

Yes

No Plugs Size: location ft. Did any strata contain unusable water? Tyes I No Address 7641 35th Ave. NE Salem, Oregon 97308 Type of water? Method of sealing strata off [Signed] Was well gravel packed?

Yes No Size of gravel: ... Contractor's License No. _2 ___ Date __10_13_72 ____, 19___ Gravel placed from ft. to ...