## WATER WELL REPORT STATE OF OREGON

WATER RESOURCES DEPT. STIEM CRECON

State Well No.	65/2W	-Ilas
ARI	- /	
State Permit No	). ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	

(1) OWNER:	(10) LOCATION OF WELL:		
Name Clayton McCullough	County Marion Driller's well	l number 2692	
Address 8399 Roanoke Dr. N.E.	NE ¼ NE ¼ Section 14 T. 6S	R. 2W W.M.	
City Brooks, Oregon 97305 State	Tax Lot # Lot Blk	Subdivision	
(2) TYPE OF WORK (check):	Address at well location: 8399 Roanoke D	r.	
New Well M Deepening  Reconditioning  Abandon	(11) WATER LEVEL: Completed w	ell.	
If abandonment, describe material and procedure in Item 12.	Depth at which water was first found 35	ft.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):		and surface. Date 5/29/8	
Rotary Air 🐰 Driven 🗆 Domestic 🖳 Industrial 🗆 Municipal 🗆		er square inch. Date	
Rotary Mud	(12) WELL LOG: Diameter of well below casing		
(5) CASING INSTALLED: Steel N Plastic	Depth drilled 161 ft. Depth of	completed well 161 ft.	
Threaded  Welded  Weld	Formation: Describe color, texture, grain size and str thickness and nature of each stratum and aquifer pene for each change of formation. Report each change in and indicate principal water-bearing strata.	trated, with at least one entry	
		- <del></del>	
LINER INSTALLED:	MATERIAL	From To SWL	
"Diam. from ft. to ft. Gauge	Topsoil	0 2	
(6) PERFORATIONS: Perforated? X Yes □ No	Brown Clay	2 21	
Type of perforator used Mills Knife	Blue Clay	21 35	
Size of perforations $3/8$ in by $2\frac{1}{2}$ in .	Black Sand and Clay	35 53	
432 perforations from 125 ft. to 155 ft.	Black Sand	53 77	
perforations from	Black Sand and Gravel	77 80	
perforations fromft. toft.	Blue Clay	80 94	
	Black Sand w/ some gravel	94 117	
(7) SCREENS: Well screen installed? ☐ Yes 🏋 No	Black Sand and Gravel	117 121	
Manufacturer's Name	Sandy Black Sand & Gravel	121 125	
Type Model No.	Black Sand and Gravel	125 127	
Diam. Slot Size	Brown Sand and Bravel	127 141	
Diam. Slot Size Set from ft. to ft.	Black Sand and Gravel	141 155	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	_Blue_Clay	155 161	
Wes a pump test made?    Yes X No If yes, by whom?		<del></del>	
d: gal/min. with ft. drawdown after hrs.		<del> </del>	
" " " "		<del> </del>	
Air test 300+ gal./min. with drill stem at 160ft. 1 hrs.		<del>                                     </del>	
Bailer test gal./min. with ft. drawdown after hrs.		<del>                                     </del>	
Astesian flow g.p.m.		<del>   </del>	
perature of water Depth artesian flow encountered ft.		<u></u>	
	Work started 5/27/87 19 Complet	· · · · · · · · · · · · · · · · · · ·	
(9) CONSTRUCTION: Special standards: Yes □ No \(\overline{X}\)	Date well drilling machine moved off of well	5/29/87 19	
Well seal—Material used Dry 8-mesh Benetonite  Well sealed from land surface to 19 ft.	Drilling Machine Operator's Certification:		
	This well was constructed under my direct s	upervision. Materials used	
Diameter of well bore to bottom of seal	and information reported above are true to my b	est knowledge and heller.	
Diameter of well bore below sealin.	(Drilling Machine Operator)	Date, 19	
Number of sacks of cement used in well seal 0	Drilling Machine Operator's License No83	L1	
bentonite placed into dry annular space	Water Well Contractor's Certification:	<del></del>	
immediately after place nt of first casing.			
Was pump installed?	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.	Name WILLAMETTE DRILLING CO.	******************************	
Did any strata contain unusable water? Yes No	Name WILLAMETTE DRILLING CO. (Type or print)  Address 1/50 Reproducts P.d. N. F. C. 1. OR O'Teco.		
Type of Water? depth of strata	Address 1450 Barnick Rd. N.E. Salem, OR 97303		
Method of sealing strata off	[Signed]	********************	
Was well gravel packed? ☐ Yes ☐ No Size of gravel:	(Water Well Contract	•	
Gravel placed from	Contractor's License No7.53Date6/.1	<b>≠8719</b>	
NOTICE TO WELL CONTRACTOR	WATER PEGOLINGER PERAPETER		