NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON

(Do not write above this line)

State Well No. 6/2 10 -14 L

State Permit No. ...

G-4113

(1) OWNER:	(11) LOCATION OF WELL:
Name John H. Bisan	County Marion Driller's well number 1257
Address Rt. 1 Box 279 Aurora, Oregon	¼ ¼ Section 14 T. 6 R. 2W W.M.
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner
New Well Deepening Reconditioning Abandon □ If abandonment, describe material and procedure in Item 12.	NA.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well below casing
Cable 🔟 Jetted 🗌 Domestic 🗎 Industrial 🗎 Municipal 🗍	Depth drilled 80 ft. Depth of completed well 80 ft.
Dug Bored Irrigation Test Well Other	Formation: Describe color, texture, grain size and structure of materials;
CASING INSTALLED: Threaded Welded To 10 " Diam from top ft to 80 ft Gage 250	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.
" Diam. fromft. toft. Gage	MATERIAL From To SWL
" Diam. from ft. to ft. Gage	Top soil 0 1
PERFORATIONS: Perforated? TY Yes No.	Brown clay 1 20
Type of perforator used Mills	Gray clay 20 40
	Brown sand & Gravel 40 73
Size of perforations 2 in. by 3/8 in. 350 perforations from 79 ft. to 43 ft.	Gray clay 73 75
t .	Black sand & gravel 75 80 100
perforations fromft. toft. perforations fromft. toft.	
perforations from ft. to ft.	
perforations from ft. to ft.	
(7) SCREENS: Well screen installed? Yes No	
Manufacturer's Name	
Type	
Diam. Slot size Set from ft. to ft.	
(8) WATER LEVEL: Completed well.	
Static level 10 ft. below land surface Date8/31/67	
A lian pressure lbs. per square inch Date	
(9) WELL TESTS: Drawdown is amount water level is	
lowered below static level Was a pump test made? Tyes \(\subseteq \text{No if yes, by whom? Driller} \)	
	Work started 8/25/67 19 Completed 8/31/67 19
	Drilling Machine Operator's Certification: This well was constructed under my direct supervision. Mate-
Bailer test gal./min. with ft. drawdown after hrs.	rials used and information reported above are true to my best knowledge and belief.
Artesian flow g.p.m. Date	4.1. A 1.4 11
Temperature of water 5 Was a chemical analysis made? Yes No	[Signed] X XV Wather Operator) Date 8/31/679
(10) CONSTRUCTION: well seal—Material used Coment & Puddle clay	Drilling Machine Operator's License No151
Depth of seal	Water Well Contractor's Certification:
Diameter of well bore to bottom of seal 14 in.	This well was drilled under my jurisdiction and this report is
Were any loose strata cemented off? 🗋 Yes XNo Depth	frue to the best of my knowledge and belief.
Was a drive shoe used? T Yes 🔲 No	NAME WILLAMETTE DRILLING COMPANY (Person, firm or corporation) (Type or print)
Did any strata contain unusable water? 🔲 Yes 🔼 No	· · · · · · · · · · · · · · · · · · ·
Type of water? depth of strata	Address Rt. 2 Box 276, Salem, Oregon
Method of sealing strata off	[Signed] Bolos
Was well gravel packed? ☐ Yes No Size of gravel:	(Water Well Contractor)
Gravel placed fromfttoft.	Contractor's License No. 2 Date 9/1/67