

**NOTICE TO WATER WELL CONTRACTOR**

The original and first copy of this report are to be filed with the

**WATER WELL REPORT**

STATE ENGINEER, SALEM, OREGON 97810  
within 30 days from the date of well completion.

STATE OF OREGON

(Please type or print)  
(Do not write above this line)

MARI... 40/0  
G-5795  
G-4811  
G-4324

State Well No. 6/2w-14 N

State Permit No.

APR 28 1968

**(1) OWNER:**

Name H. D. Coomber  
Address 6796 - 62nd Ave. N.E. Salem

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

10" Diam. from 1 ft. to 80 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

**(6) PERFORATIONS:**

Perforated?  Yes  No  
Type of perforator used Wells  
Size of perforations 5/8 in. by 2 in.  
410 perforations from 0 ft. to 58 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

**(8) WATER LEVEL: Completed well.**

Static level 1 ft. below land surface Date 3-22-68  
Artesian pressure lbs. per square inch Date

**(9) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Miller & Robinson  
Yield: 350 gal./min. with 22 ft. drawdown after 2 hrs.  
425 " 29 " 3 1/2  
500 " 40 " 3 1/2  
700 " 58 " 2 1/2  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made?  Yes  No

**(10) CONSTRUCTION:**

Well seal—Material used BENTONITE  
Depth of seal 20 ft.  
Diameter of well bore to bottom of seal 19 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

**(11) LOCATION OF WELL:**

County MARION Driller's well number  
1/4 Section 14 T. 6, S. R. 7 W W.M.  
Bearing and distance from section or subdivision corner

**(12) WELL LOG:**

Diameter of well below casing 10  
Depth drilled 80 ft. Depth of completed well 80 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Black - Soil	0	8	
Brown - CLAY	8	25	
Blue - "	25	34	
Small + Med. GRAVEL + SAND	34	60	
Blue - CLAY	60	72	
Med + Small GRAVEL + SAND	72	80	

Work started 3-19-68 19 Completed 3-22 19 68  
Date well drilling machine moved off of well 3-23- 19 68

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Walter F. Smith Date 3-23, 1968  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 529

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Miller, Robinson & West  
(Person, firm or corporation) (Type or print)

Address 5545 JOSEPH ST. S.E. SALEM

[Signed] Harold R. Miller  
(Water Well Contractor)

Contractor's License No. 37 Date 3-23, 1968