

RECEIVED

MAR 19 1966 4015

App'l No - G-4521

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

WATER WELL REPORT # G-4026
STATE OF OREGON (Please type or print)

State Well No. 6/2w-14 R
State Permit No.

(1) OWNER: Glen Groah
Name: Glen Groah
Address: Rt 2 Box 242a Silverton, Oreg.

(2) LOCATION OF WELL:
County: Marion Driller's well number:
Bearing and distance from section or subdivision corner:
850 ft. ~~west~~ west & 260 ft. north of S.E. corner of section 14, T.6.S. R.2 W.

(3) TYPE OF WORK (check):
Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL: Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED: 10" Diam. from 1' above ft. to 161 ft. Gage .279
Threaded Welded

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used: Mills
Size of perforations: 3/8 in. by 4 in.
91 perforations from 91 ft. to 159 ft.
918 perforations from ft. to ft.

(8) SCREENS: Well screen installed? Yes No
Manufacturer's Name: Model No:
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Well seal—Material used in seal: Bentonite & cuttings
Depth of seal: 20 ft. Was a packer used? no
Diameter of well bore to bottom of seal: 13 in.
Were any loose strata cemented off? Yes No
Was a drive shoe used? Yes No
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water: depth of strata
Method of sealing strata off

(10) WATER LEVELS: Static level: 5 ft. below land surface Date: 5/1/66
Artesian pressure: lbs. per square inch Date:

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Yield: 525 gal./min. with 57 ft. drawdown after 7 hrs.
Baller test: XX gal./min. with XX ft. drawdown after X hrs.
Artesian flow: g.p.m. Date
Temperature of water: XX Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing: none
Depth drilled: 161 ft. Depth of completed well: 153 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil brn.	0	2
Clay grey	2	8
Clay grey sandy	8	28
Med conglomerate brn	28	39
Clay brn. sandy	39	50
Clay blue	50	59
Med conglom grey	67	88
Loose gravel grey	88	96
med conglom grey	96	122
	122	155
Loose gravel & sand	155	157
Med conglom brn.	158	162

Filled back with #2 round gravel to 153ft

Work started 4/9 166 Completed 5/2 66
Date well drilling machine moved off of well 5/12 66

(13) PUMP: Manufacturer's Name: Jacuzzi
Type: Turbine H.P. 20

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME: R. Stadel & Sons (Type or print)
Address: Rt 3 Box 169, Silverton, Oreg.
Drilling Machine Operator's License No. 216
[Signed] Paul R. Stadel (Water Well Contractor)
Contractor's License No. 296 Date 10-19-1966