TICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER WELL REPORT

water resources department. APA 1 198 STATE OF OREGON (SALEM, OREGON 9731 ATER RESOURCES DEPT of well completion. SALEM, OREGON Not write above this line)

M 3.31.4.00 State Well No. 4s/1w-10aa State Permit No. ..

1) OWNER:	(10) LOCATION OF WELL:		
Name CONSTANTERN MARTOSHEY	County Macion Driller's well number		
Address 13000 FROLOV DR	NE 14 NE 14 Section 10 T. 45 R. 141 W.M.		
GERVIS, Or	Bearing and distance from section or subdivisi	lon corner	
(2) TYPE OF WORK (check):			
New Well		#	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	zell.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found	// ft.	
Rotary Driven Domestic Industrial Municipal		surface. Date (MAR 8	
Cable Jetted	Artesian pressure lbs. per square inch. Date		
S " Diam. from O ft. to It. Gage O. 250 C " Diam. from O ft. to S ft. Gage O. 250 C " Diam. from O ft. to S ft. Gage O. 250 " Diam. from O ft. to ft. Gage O. 250	(12) WELL LOG: Diameter of well below casing Depth drilled /55 ft. Depth of completed well /35 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,		
PERFORATIONS: Perforated? Yes No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.		
Type of perforator used STAR	MATERIAL	From To SWL	
Size of perforations 3/16 1/4 in. by 1/2 in.	TOPSOIL	0 3	
700 perforations from 86 ft. to 125 ft.	SILT BROWN	3 11 4	
perforations from ft. to ft.	CLAY BROWN	11 33	
perforations fromft. toft.	SAND, BROWN, FINE	33 39	
(7) SCOTENS.	CLAY , BROWN	39 48	
(7) SCREENS: Well screen installed? ☐ Yes ☐ No	CLAY, Grey, Silty	48 67	
Manufacturer's Name Type Model No	SAUS BLACK, FINE	69 69 19	
Diam. Slot size Set from ft. to ft.	SILT BLACK	78 81 19	
Diam. Slot size Set from ft. to ft.	CLAY GREY	81 97	
	CLAY BROWN	97 105	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	CLAY BROWN SILTY	105 111	
Was a pump test made? Pres No If yes, by whom? Dricks.	SANDETONE BLACK	111 118	
d: 110 gal./min. with 80 ft. drawdown after 5 hrs.	CEMENT GRAVEL	118 126	
g" " " " " " " " " " " " " " " " " " "	CLAY GERY	126 143	
и и и	CLAY BLUE	143 155	
Bailer test gal./min. with ft. drawdown after hrs.			
esian flow g.p.m.			
mperature of water Depth artesian flow encountered ft.	Work started MAR 6 19 80 Comple	ted MARZZ 1980	
(9) CONSTRUCTION:	Date well drilling machine moved off of well 26 MBQ 1980		
Well seal—Material used Cament	Drilling Machine Operator's Certification		
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used and information reported above are true to my		
Diameter of well bore to bottom of sealin.	best knowledge and belief.		
Diameter of well bore below seal in.	[Signed] (Drilling Magnine Operator) Date Mark 21, 1980		
Number of sacks of cement used in well seal	Drilling Machine Operator's License No		
How was cement grout placed? Pump	Water Well Contractor's Certification:		
	This well was drilled under my jurisdiction and this report is		
Was a drive shoe used? ✓ Yes ☐ No Plugs Size: location ft.	true to the best of my knowledge and belief.		
Did any strata contain unusable water? Yes No	Name (Person, firm or corporation) (Type or print)		
Type of water? depth of strata	Address 10300 St Cump Nows		
Method of sealing strata off	[Signed] June (Water Well Contractor)		
Was well gravel packed? Yes No Size of gravel:	1/2	Mar 21, 1983	
Gravel placed from	Contractor's License No Date	<u> </u>	