

MARI...

4036
6-6338

See 16?

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED
AUG 17 1966

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

STATE OF OREGON
STATE ENGINEER
SALEM, OREGON

State Well No. 6/2w-15
State Permit No.

(1) OWNER:

Name VERA O BASSETT
Address RT. I BOX 231
BROOKS, OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number II65
1/4 1/4 Section I5 T. 6 S R. 2 W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED:

Threaded Welded
10" Diam. from TOP ft. to I46 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used MILLS
Size of perforations 2 in. by 3/8 in.
400 perforations from ft. to ft.
70 perforations from 90 ft. to I25 ft.
perforations from I40 ft. to I45 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUDDLE CLAY
Depth of seal 20 ft. Was a packer used?
Diameter of well bore to bottom of seal I2 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 36 ft. below and surface Date 8/8/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? DRILLER
Yield: 400 gal./min. with I9 ft. drawdown after 6 hrs.
" 500 " 29 " 6 "
" 600 " 38 " 6 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing

Depth drilled I46 ft. Depth of completed well I46 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	2
BROWN SOIL SILT	2	44
BLUE CLAY	44	55
BLUE SHALE & BLACK SHALE	55	79
SCATTERED SAND & GRAVEL	79	85
BLACK SAND & LARGE GRAVEL	85	I09
BROWN SAND & GRAVEL	I09	II5
BROWN SAND & SCATTERED GRAVEL	II5	II7
BLACK SAND & GRAVEL	II7	I25
BROWN SAND	I25	I40
BLACK SAND & GRAVEL	I40	I46

Work started JULY 25 1966 Completed AUG 8 1966
Date well drilling machine moved off of well AUG. 8 1966 19

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO.
(Person, firm or corporation) (Type or print)

Address RT. 2 BOX 276 SALEM, OREGON

Drilling Machine Operator's License No. 470

[Signed] Emil O. Beier
(Water Well Contractor)

Contractor's License No. 2 Date AUG 8 1966, 19