

RECEIVED JUN 12 1964 MARI... 4039

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

State Well No. 6/2w-15

State Permit No.

(1) OWNER:

Name JOSEPH HENNY Address RT. 1 BOX 216 BROOKS, OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number 924 1/4 Section 15 T. 6S R. 2W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [x] Deepening [ ] Reconditioning [ ] Abandon [ ] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [x] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [x] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED:

8" Diam. from TOP ft. to 80 ft. Gage 250

(7) PERFORATIONS:

Perforated? [x] Yes [ ] No Type of perforator used MILLS Size of perforations 3/8 in. by 2 in. 208 perforations from 35 ft. to 45 ft. & 70 ft. to 79 ft.

(8) SCREENS:

Well screen installed? [ ] Yes [x] No Manufacturer's Name Type Model No. Slot size Set from ft. to Diam. Slot size Set from ft. to

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUDDLE CLAY Depth of seal 18 ft. Was a packer used? Diameter of well bore to bottom of seal 10 in. Were any loose strata cemented off? [ ] Yes [ ] No Depth Was a drive shoe used? [x] Yes [ ] No Was well gravel packed? [ ] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusuable water? [ ] Yes [ ] No depth of strata Type of water? Method of sealing strata off

(10) WATER LEVELS:

Static level I ft. below land surface Date 5/27/64 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [ ] No If yes, by whom? DRILLER Yield: 270 gal./min. with 15 ft. drawdown after 4 hrs. " 330 " 20 " 4 " " 370 " 23 " 4 " test 400 gal./min. with 25 ft. drawdown after 4 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [ ] Yes [ ] No

(12) WELL LOG:

Diameter of well below casing Depth drilled 80 ft. Depth of completed well 80 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifiers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO. Rows include TOP SOIL, CLAY, SAND & GRAVEL, CLAY, SAND, CEMENT GRAVEL, GRAVEL.

Work started MAY 25 1964 . Completed MAY 28 19 64 Date well drilling machine moved off of well MAY 28 1964

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO (Person, firm or corporation) (Type or print)

Address RT. 2 BOX 276 SALEM, OREGON

Drilling Machine Operator's License No. I79

[Signed] Emil O. Beier (Water Well Contractor)

Contractor's License No. 2 Date MAY 28 1964 19