

Stettler Supply Co.

1810 Lana Ave.

Salem, Oregon

6/2w-15 Hc

Marion

3-7, 1969

WELL TEST CARD

Well Diameter 10" Depth 120 Cased to 120

Well straight? Yes Depth after pumping

Well casing perforated at 86 - 111

Formation of water bearing strata

Test pump setting 108 Length of air line 100

Static level - Before test 16' After test

Static air pressure

Capacity	Pressure on air line	Pumping level	Time
660 GPM	28 Lbs.	35 Feet	3/4 hr Minutes
760	24	45	1/2 hr
900	22	49	15 min

Just Pumping 45 min

Did well clear up? Yes

Name John Hay Address

RECEIVED MAR 12 1969 STATE ENGINEER

11-12-68

