NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 9731 within 30 days from the date of well completion.

## WATER WELL REPORT CEIVED

STATE OF OREGON

AUG 9 1976.....

STATE ENGINEER, SALEM, OREGON 97310 (Please type within 30 days from the date of well completion. (Do not write a	e or print) AUG 9 1976 State Permit N. State Permit N. State Permit N. Deve this IMPER RESOURCES DEPT.	. 65/zw-	76
	SALEM, CRECON		
(1) OWNER:	(10) LOCATION OF WELL:		
Name Douglas Mandal	County Marion Driller's well number 1976		
AddressRt. 1 Box 328 R Gervais, Oregon 97026	1/4 1/4 Section 16 T. 6S R. 2W W.A		
(0) HTTPT OF TYONG (1)	Bearing and distance from section or subdivision	on corner	
(2) TYPE OF WORK (check):			
New Well Deepening Reconditioning Abandon			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.		
(3) TYPE OF WELL: (4) PROPOSED USE (check):			
Rotary Driven Domestic Industrial Municipal Domestic Industrial Municipal			<u>f</u>
January III	Static level 37 ft. below land surface. Date 7/22/76		
Dug   Bored   Irrigation Test Well   Other	Artesian pressure lbs. per square	e inch. Date	
CASING INSTALLED: Threaded Welded To to 101 ft. Gage • 250	(12) WELL LOG: Diameter of well b		
ft. Gage	Depth drilled 101 ft. Depth of completed well 101 ft		
"Diam from ft. to ft. Gage	Formation: Describe color, texture, grain size a and show thickness and nature of each stratum	nd structure of ma	iterials
PERFORATIONS: Perforated? Yes   No.	with at least one entry for each change of format position of Static Water Level and indicate princ	ion. Report each chi	anae i
Type of perforator used Mills Knife Perforator	MATERIAL	From To	swl
Size of perforations 3/8 in. by 2 in.	Topsoil	0 2	
288 perforations from	Brown silty @lav	2 16	
perforations from ft. to ft.	Blue Silty Clay	16 69	
perforations from ft. to ft.	Brown sandand gravel	69 86	
(E) COPERAG	Black sand and Gravel	86 98	
(7) SCREENS: Well screen installed?   Yes   No	Cemented Brown Sand and Gravel	98 101	
Manufacturer's Name		70   201	
Type Model No.			
Diam Slot size Set from ft. to ft.			
Diam. Slot size Set from ft. to ft.			
(8) WELL TESTS: Drawdown is amount water level is lowered below static level			
Was a pump test made? T Yes I No If yes, by whom? driller			
Yield:250 gal./min. with 4 ft. drawdown after 1 hrs.			
350 " 8 " 1 "			
r00			
		<del></del>	
Bailer test gal./min. with ft. drawdown after hrs.			
Artesian flow g.p.m.			
sperature of water 53 Depth artesian flow encountered ft.	Work started 7/17/76 19 Completed	17/22/76	19
(9) CONSTRUCTION:	Date well drilling machine moved off of well	7/22/76	19
Well seal-Material used Portland Coment	Drilling Machine Operator's Certification:		
Well sealed from land surface to	This well was constructed under my	direct supervi	sion.
Diameter of well bore to bottom of sealin.	Materials used and information reported a best knowledge and belief.	bove are true to	o my
Diameter of well bore below seal	1 25 1 44 11 5 5 5	7/23/76	
Number of sacks of cement used in well seal sacks	(Drilling Machine Operator)		
Number of sacks of bentonite used in well seal sacks	Drilling Machine Operator's License No	752	
Brand name of bentonite	W-4-W N G		
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:		
of waterlbs./100 gals.	This well was drilled under my jurisdic	tion and this rep	ort is
Was a drive shoe used? 🗷 Yes 🗌 No Plugs Size: location ft.	with the best of my knowledge and belie	ef.	
Did any strata contain unusable water? 🔲 es 💂 No	Name Willamette Driling Co. (Person, firm or corporation)	(Type or min')	
Type of water? depth of strata	Address 1450 Barnick Rd. NE Sale	m. One or print)	,3 <b>0</b> 0
Method of sealing strata off	[Signed] Nalles & Decis	**************************************	<u>ر</u> Ωدٍ
Was well gravel packed?  Yes No Size of gravel:	(Water Well Contrac	tor)	
Gravel placed from ft. to ft.	Contractor's License No. 561 Date 7	/23/76 1	10