



Stettler Supply Co.

1810 Lana Ave.

Salem, Oregon

2/2w-16  
Marion

2-28, 1969

WELL TEST CARD

Well Diameter 12" Depth 154 Cased to.....

Well straight?..... Depth after pumping.....

Well casing perforated at.....

Formation of water bearing strata.....

Test pump setting 148 Length of air line 130

Static level - Before test 16 After test.....

Static air pressure.....

Capacity	Pressure on air line	Pumping level	Time
<u>550</u> GPM	<u>40</u> Lbs.	<u>37</u> Feet	<u>15</u> Minutes

<u>660</u>	<u>42</u>	<u>33</u>	<u>1 hr</u>
------------	-----------	-----------	-------------

<u>500</u>	<u>43</u>	<u>31</u>	<u>1/2 hr</u>
------------	-----------	-----------	---------------

Test Pumping 45 min

Did well clear up? Yes

Name Carl J. Doe  
Address

RECEIVED  
MAR 12 1969

10-91-68

STATE ENGINEER  
SALEM, OREGON

