## STATE OF OREGON

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)	MARI 176a Reigid.
(1) OWNER: Name Norpac Foods Inc.	(9) LOCATION OF WELL by legal description:  County Marion Latitude Longitude
Address PO Box 458	Township 6 S Nor S, Range 2 W E or W, WM.
City Stayton State OR Zip 97383	Section 17 NE 14 NW 14
(2) TYPÉ OF WORK:	Tax Lot Lot Block Subdivision
New Well Deepen Recondition Abandon	Street Address of Well (or nearest address) 4755
(3) DRILL METHOD	Brooklake Rd NE
Rotary Air Rotary Mud Cable	(10) STATIC WATER LEVEL:
Other	ft. below land surface. Date
(4) PROPOSED USE:  ☐ Domestic ☐ Community	Artesian pressure lb. per square inch. Date
☐ Thermal ☐ Injection ☐ Other	(11) WATER BEARING ZONES:
RORE HOLE CONSTRUCTION:	Depth at which water was first found
al Construction approval Yes No Depth of Completed Well 143 ft.	From To Estimated Flow Rate SWL
Yes No L	
HOLE SEAL Amount Diameter From To Material From To sacks or pounds	
4 0 35 Bentonite 5 35 53	(12) WELL LOG:
	Ground elevation
	Material From To SWL
How was seal placed: Method	We drilled a 6" hole along
Other	side the 12" well we in-
Backfill placed fromft. toft. Material	But back Tilled with Paravel
Gravel placed from ft. to ft. Size of gravel	to 50 ft than put in chushed
(6) CASING/LINER:	rock for seal than bentonite.
Diameter From To Gauge Steel Plastic Welded Threaded	Crushed rock from 50-45'
Casing:	We drilled along side Well
	to 35' for a new seal
	Rumped in 44 Sacts
Liner:	bentonite to with in 2/2
Final location of shoe(s)	feet of sufface than
	Surface.
, PERFORATIONS/SCREENS:	SUFFACE
☐ Perforations         Method           ☐ Screens         Type	
Slot Tele/pipe	
To size Number Diameter size Casing Liner	
	Date started July 7 1987 Completed July 10 1987
	(unbonded) Water Well Constructor Certification:
(8) WELL TESTS: Minimum testing time is 1 hour Flowing	I certify that the work I performed on the construction, alteration, or
□ Pump □ Bailer □ Air □ Artesian	abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my best
Yield gal/min Drawdown Drill stem at Time	knowledge and belief.
1 hr.	Simulation of State o
	Signed Date 7 13/8
	(bonded) Water Well Constructor Certification:
Temperature of water Depth Artesian Flow Found	I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. all
Was a water analysis done?	work performed during this time is in compliance with Oregon well construction standards. This report is true to the best of my knowledge and
☐ Salty ☐ Muddy ☐ Odor ☐ Colored ☐ Other	belief.  WWC Number, 13
Depth of strata:	Signed Heory Colman Date 7-13-87