

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

RECEIVED WATER WELL REPORT
MAR 22 1974 STATE OF OREGON
DEC 26 1974
State Well No. MAR 4116
3/2W 17

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE ENGINEER
SALEM, OREGON
State Permit No.

(1) OWNER: 393 2569

X Name GREEN OAKS Mobil Park
Address 9255 Portland Rd N.E.
% Bob Swope Brooks ORF

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):
Rotary Driven Domestic Industrial Municipal
Cable Jetted Irrigation Test Well Other
Dug Bored

CASING INSTALLED:
8" Diam. from 0 ft. to 169 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? Yes No.
Type of perforator used Mills
Size of perforations 1/2" in. by 1 1/2" in.
648 perforations from 125 ft. to 165 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: 200 gal./min. with 20 ft. drawdown after 4 hrs.
~~200 gal./min. with 20 ft. drawdown after 4 hrs.~~
" " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION: CEMENT GROUT
Well seal—Material used
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 10 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County MARION Driller's well number
1/4 1/4 Section 17 T. 6-S R. 2 W W.M. X
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 25 ft.
Static level 15 ft. below land surface. Date 3-7-74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing
Depth drilled 169 ft. Depth of completed well 169 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brown Clay	0	26	
Brown Sandy clay	26	35	
Brown Clay	35	37	
Blue Clay	37	50	
GRAY CLAY	50	61	
BLUE SANDY CLAY	61	70	
BLUE SAND & GRAVEL (GRAV)	70	85	
BLACK SAND & GRAVEL	85	95	
BROWN GRAVEL & SAND	95	135	
BLUE CLAY & GRAVEL	135	137	
BLUE GRAVEL & SAND (GRAV)	137	141	
BROWN GRAVEL & SAND	141	165	
BLUE CLAY	165	169	

Work started 2-5 1974 Completed 3-8 1974
Date well drilling machine moved off of well 3-8 1974

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Paul P. Dickerson Date 3-7-1974
(Drilling Machine Operator)
Drilling Machine Operator's License No. 549

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name ROBINSON'S FOIA WELL DRILLING (Type or print)
Address 4510 DALLAS RD., N.W. SALEM, OREGON 97304
[Signed] George H. Robinson (Water Well Contractor)
Contractor's License No. 13 Date 3-20, 1974