

MAR 4/39

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED SEP 13 1965 STATE ENGINEER SALEM OREGON

WATER WELL REPORT

State Well No. 6/2w-17 State Permit No.

(1) OWNER:

Name DON G. VANDOPVORT Address RT. 1 BOX 71 BROOKS, OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number I076 1/4 Section I7 T. 6 S R. 2 W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other [] Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

Threaded [] Welded [X] 6" Diam. from TOP ft. to 100 ft. Gage 250

(7) PERFORATIONS:

Perforated? [] Yes [X] No Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUTTLE CLAY Depth of seal 20 ft. Was a packer used? Diameter of well bore to bottom of seal 8 in. Were any loose strata cemented off? [] Yes [] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 32 ft. below land surface Date 8/24/65 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level. Was a pump test made? [] Yes [X] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 40 gal./min. with 20 ft. drawdown after I hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well below casing Depth drilled I00 ft. Depth of completed well I00 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: TOP SOIL (0-2), YELLOW CLAY (2-31), SILTY BROWN SAND (31-35), BLUE CLAY (35-65), BLACK SAND (65-80), BLACK SAND & GRAVEL (80-100)

Work started AUG. 19 1965 Completed AUG. 24 19 65 Date well drilling machine moved off of well AUG. 24 19 65

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO. (Person, firm or corporation) (Type or print)

Address RT. 2 BOX 276 SALEM, OREGON

Drilling Machine Operator's License No. 393

[Signed] Emil O. Beier (Water Well Contractor)

Contractor's License No. 2 Date AUG. 24 19 65