

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy
 of this report are to be
 filed with the
 STATE ENGINEER, SALEM 10, OREGON
 within 30 days from the date
 of well completion.

MAR. 4/57

WATER WELL REPORT
 STATE OF OREGON
 (Please type or print)

State Well No. 6/2W-17
 State Permit No. _____

(1) OWNER:

Name Oak Crest Farm
 Address 2770 Wallace Rd. NW
Salem, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number 6/2W-17
 1/4 Section T. R. W.M.
 Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED:

Threaded Welded
1 3/4" Diam. from 140 ft. to 119 1/2 ft. Gage 250
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used Mills
 Size of perforations 5/16 in. by 2 1/4 in. 12 rows
516 perforations from 90 ft. to 118 ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
 Manufacturer's Name _____ Model No. _____
 _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal sand
 Depth of seal 20 ft. Was a packer used? no
 Diameter of well bore to bottom of seal 14 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 11 ft. below land surface Date 5/16/62
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: 1140 gal./min. with 77 ft. drawdown after 1 hrs.
 " 950 " " 62 " " 1 "
 " 787 " " 51 " " 1 "
 Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 12"
 Depth drilled 120 ft. Depth of completed well 120 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil & clay	0	10
Silty clay (yellow)	10	25
Silty clay (gray)	25	65
Black sand	65	85
Sand & gravel	85	120

Work started 5/1 1962 Completed 5/16/62 19
 Date well drilling machine moved off of well 5-17-62 19

(13) PUMP:

Manufacturer's Name _____ Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Harry A. Robinson (Person, firm or corporation) (Type or print)
 Address 2214 Front St. NE Salem, Ore.
 Drilling Machine Operator's License No. 22
 [Signed] Harry A. Robinson (Water Well Contractor)
 Contractor's License No. 22 Date 5/18/62, 19