NOTICE TO WATER WELL CONTRACTOR/

The original and first copy of this report are to be

of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

KEULIVEN

WATER WELL REPORT JAN 3 1 1975
STATE OF OREGON
(Please type or print)
STATE ENGINEER

STATE Permit No. (Do not write above this line) SALEM. OREGON Permit No.

(1) OWNER:	(10) LOCATION OF WELL:	
Name James Ditter	County Morion Driller's well number	1872
Address 9330 River Road N	14 14 Section 18 T. 65 R. 2.	. W.M.
Salem, Oregon	Bearing and distance from section or subdivision corn	ıer
(2) TYPE OF WORK (check):		
New Well ☑ Deepening □ Reconditioning □ Abandon □		
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 108 ft.	
Rotary Driven Domestic Dindustrial Municipal	Static level 25 ft. below land surface.	
Cable	Artesian pressure Ibs. per square inch. Date	
CASING INSTALLED: Threaded Welded \(\overline{\text{Threaded}} \) Welded \(\overline{\text{Z}} \)	(12) WELL LOG: Diameter of well below casing	
"Diam from tt to ft. Gage	Depth drilled 147 ft. Depth of completed well 147 ft.	
" Diam. fromft. Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,	
Diam. Hom	with at least one entry for each change of formation. Re-	eport each change in
PERFORATIONS: Perforated? No.	position of Static Water Level and indicate principal w	ater-bearing strata.
Type of perforator used 1511g	MATERIAL From	To SWL
Size of perforations 7/16 in. by 2 3/4 in.	Top Soil 0	2
390 perforations from 170 ft. to 145 ft.	Yellow Glav 2	35
perforations fromft. toft.	Blue Clay 35	108
perforations fromft. toft.	Brown sand & gravel 108	145
	Blue Clay 145	147
(7) SCREENS: Well screen installed? Yes No		
Manufacturer's Name		
Type Model No		
Diam. Slot size Set from ft. to ft.		
Diam. Slot size Set from ft. to ft.		
(8) WELL TESTS: Drawdown is amount water level is lowered below static level		
Was a pump test made? ☑ Yes ☐ No If yes, by whom? intiler		<u> </u>
Zield: 300 gal./min. with 70 ft. drawdown after 5 hrs.		
550 " 75 " same"		
" 400 " BO " same"		
Bailer test gal./min. with ft. drawdown after hrs.		
Artesian flow g.p.m.		
perature of water Depth artesian flow encountered ft.	Work started 12-12-74 19 Completed 1	L-16-75 19
(9) CONSTRUCTION:	Date well drilling machine moved off of well	L-16-75 19
Well seal-Material used	Drilling Machine Operator's Certification:	
Well sealed from land surface toft.	This well was constructed under my dire Materials used and information reported above	ct supervision. e are true to mv
Diameter of well bore to bottom of seal 14 in.	best knowledge and belief.	
Diameter of well bore below sealin.	[Signed] Chanald W. Morton Date (Drilling Machine Operator)	1-16-75, 19
Number of sacks of cement used in well seal11sacks	Drilling Machine Operator's License No. 536	
Number of sacks of bentonite used in well seal sacks	Drining Machine Operator's License 140.	
Brand name of bentonite	Water Well Contractor's Certification:	
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.	This well was drilled under my jurisdiction and this report is	
was a drive shoe used? Tyes No. Plugs Size: location ft.	true to the best of my knowledge and belief.	
Did any strata contain unusable water Yes No	Name WILL TETT DETITING CO PANY (Person, firm or corporation) (Type or print)	
Type of water? depth of strata	Address 7641 35th Ave. NR S.lem, Oregon	
Method of sealing strata off	- [Signed] Cmild Zeier	
Was well gravel packed? ☐ Yes ☐ No Size of gravel:	(Water Well Contractor) Contractor's License No. 2 Date 1-16-	-75
Gravel placed fromft. to	Contractor & License No Date	18