

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

RECEIVED
JUN 15 1965
STATE ENGINEER OF OREGON
SALEM, OREGON

MAR 4231

WATER WELL REPORT

State Well No. 6/2W-19
 State Permit No. _____

(1) OWNER:

Name TERMINAL ICE & COOL STORAGE CO.
 Address 965 COMM. N.E. SALEM ORE.

(2) LOCATION OF WELL:

County MARION Driller's well number _____
 1/4 Section SE-19 T. 6, S. R. 2 W W.M.
 Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded

10" Diam. from 71 ft. to 176 ft. Gage 250
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used Mills
 Size of perforations 4 in. by 2 1/2 in.
10.56 perforations from _____ ft. to _____ ft.
90 perforations from _____ ft. to 175 ft.
 perforations from _____ ft. to _____ ft.
 perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
 Slot size _____ Set from _____ ft. to _____ ft.
 Diam. Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal DRILL MUD & BENTONITE
 Depth of seal 30 ft. Was a packer used? NO
 Diameter of well bore to bottom of seal 16 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 32 ft. below land surface Date 7/16/65
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? STETTLER
 Yield: 700 gal./min. with 49 ft. drawdown after 4 hrs.

Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 10

Depth drilled 181 ft. Depth of completed well 181 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Soil	0	1
BROWN CLAY	1	54
BLUE "	54	59
BROWN "	59	60
" " & GRAVEL	60	64
BLUE "	64	84
" " "	84	90
SAND & GRAVEL	90	127
CEMENTED GRAVEL	127	129
VERY CLEAN "	129	144
WHITE CLAY	144	152
CEMENTED SAND & GRAVEL	152	161
LOOSE SAND & GRAVEL	161	171
CEMENTED " & "	171	181

Work started 4/2/65 19 Completed 4/16/65 19
 Date well drilling machine moved off of well _____ 19

(13) PUMP:

Manufacturer's Name _____
 Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Miller-Rabinow & West
 (Person, firm or corporation) (Type or print)

Address 5545 J. ST. S.E.

Drilling Machine Operator's License No. 59

[Signed] Harlan R. Miller
 (Water Well Contractor)

Contractor's License No. 37 Date 5/1/65, 19____