

RECEIVED
NOV 14 1958

M 131 (432)

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

STATE ENGINEER
OREGON

WATER WELL REPORT
STATE OF OREGON

State Well No. 6/2W-21PC1
State Permit No. C962

61192

(1) OWNER:

Name J.W. Burr
Address Salem, Oregon

(2) LOCATION OF WELL:

County Marion Owner's number, if any—
SE 1/4 SW 1/4 Section 21 T. 6 S. R. 2 W.W.M.
Bearing and distance from section or subdivision corner
Well is located N.68 deg.57'W.14.73 ch.
and S.29 deg.22'W.11.539 ch. and S.38 deg.
43'W.3.853 ch. and S.140 ft. to the Well
from the SE. corner of Thomas Moisan
D.L.C. in Sec. 21; T. 6 S. R. 2 W.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from Top ft. to 54 ft. Gage 17.02#
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated Yes No
Type of perforator used Mills
SIZE of perforations 1/2 in. by 1 in.
perforations from ft. to ft.
22 perforations from 50 ft. to 54 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? 15 ft.
Material used in seal—Puddled Clay
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 5 ft. below land surface Date 9-19-58
Artesian pressure lbs. per square inch Date

Log Accepted by

[Signed] Mrs. J.W. Burr Date 19
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? -
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 30 gal./min. with 2 ft. drawdown after 2 hrs.
Artesian flow g.p.m. Date
Temperature of water 55 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 6 inches.
Depth drilled 54 ft. Depth of completed well 54 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	2
Gray Clay	2	23
Yellow clay	23	44
Tight Gravel	44	48
Sand & Gravel	48	54
(Water)		

Work started 9-17-58, 19 Completed 9-19-58 19

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Orville Wymore
(Person, firm, or corporation) (Type or print)

Address Rt. 1 Brooks, Oregon

Driller's well number 453

[Signed] Orville Wymore
(Well Driller)

License No. 88 Date 9-20-58, 19