NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be

filed with the within 30 days from the date

STATE ENGINEER, SALEM, OREGON 973 of well completion.

WATER WELL REPRECEIVED

STATE OF OREGON AUG9 1974 State Well No. 65 2W-22
(Please type or print)

(Do not write above this IMPATE ENGINEER State Permit No. 6 6961

SÁLEM, OREGON

(1) OWNER:	(10) LOCATION OF WELL:
Name W. E. Biggins	County Marion Driller's well number 1849
Address 7215 Labish Center Road NE	34 34 Section 22 T. 6S R. 2W W.M.
Solem Oregon	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	Dearing and distance from section of subdivision corner
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐	
If abandonment, describe material and procedure in Item 12.	(11) WARRING TOWNS (11)
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL: Completed well.
	Depth at which water was first found 70 ft.
Rotary	Static level 45 ft. below land surface. Date 8-7-74
Dug Bored I Irrigation Test Well Other	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded □ Welded □	(12) WELL LOG: Diameter of well below easing
8 "Diam. from top ft. to 121 ft. Gage 250	
	Depth drilled 121 ft. Depth of completed well 121 ft.
ft. Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,
PERFORATIONS: Perforated? Yes No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata
Type of perforator used [5] 118	MATERIAL From To SWL
Size of perforations 3/8 in. by 2 in.	
264 perforations from 95 ft. to 120 ft.	Top Soil
perforations from ft. to ft.	Brown sand and gravel 70 110
perforations from ft. to ft.	Cemented gravel 110 121
periorations from	
(7) SCREENS: Well screen installed? ☐ Yes ☑ No	
Manufacturer's Name	
Type Model No	
Diam Slot size Set from ft. to ft.	
Diam Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is	
lowered below stand level	
Was a pump test made? ▼ Yes □ No If yes, by whom? Driller	
Yield: 100 gal./min. with 10 ft. drawdown after 2 hrs.	
200 " 20 " same"	
" 300 " 35 " same"	
Bailer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
perature of water Depth artesian flow encountered ft.	Work started July 29, 1974 Completed Aug. 7, 19 7
(9) CONSTRUCTION:	Date well drilling machine moved off of well Aug. 8, 1974 19
Well seal—Material usedCement	Drilling Machine Operator's Certification:
Well sealed from land surface toft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my
Diameter of well bore to bottom of seal12 in.	best knowledge and belief.
Diameter of well bore below seal8 in.	[Signed] Ranald W. Multon. Date 8-8-74, 19
Number of sacks of cement used in well sealsacks	
Number of sacks of bentonite used in well seal sacks	Drilling Machine Operator's License No536.
Brand name of bentonite	Water Well Contractor's Certification:
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdiction and this report is
of water lbs./100 gals.	true to the best of my knowledge and belief.
Was a drive shoe used? Yes □ No Plugs Size: location ft.	Name WILLAMETTE DRILLING COLLANY
Did any strata contain unusable water? Yes No	(Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address 7641 35th Ave. NE Salem, Oregon
Method of sealing strata off	[Signed] Mil ODello
Was well gravel packed? ☐ Yes ☑ No Size of gravel:	(Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No. 2 Date 3-8-74 19