NOTICE TO WATER WELL CONTRACTOR

The original and first epper of this report are token to filed with the C T WATER WELL REPORT

STATE OF OREGONA A

STATE OF OREGON A

State Well No. 65-2w-22

STATE ENGINEER, SALEM, OREGON 97205 1975
within 30 days from the date of well compared RESOURCES DEPT.

(Do not write above this line)

	j		
State	Permit	No.	

(1) OWNER:	(10) LOCATION OF WELL:		-	
Name E. T. Kasper	County Marion Driller's well n	umber	1918	
Address 6644 Lebish Center Road NE	34 34 Section 22 T. 6	R. 2W	2.7.1.12	W.M.
Salem, Oregon	Bearing and distance from section or subdivis			
(2) TYPE OF WORK (check):		.on corner		
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐				
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	11		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found		-	•••
Rotary Driven Domestic Dandustrial Demostrial Demostria		44		ft.
Cable M. Jetted D.	Static level 12 ft. below land	surface. I	Date 11	<u>-5-75</u>
Dug Bored Irrigation W Test Well Other	Artesian pressure lbs. per square	re inch. I	Date .	
CASING INSTALLED: Threaded □ Welded ☑	(12) WELL LOG: Diameter of well			
10 " Diam. from top ft. to 112 ft. Gage 250	13.0			
	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,			
PERFORATIONS: Perforated? W. Ves. Cl. No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.			
i dipinica: 2 100	position of Static Water Lebet and indicate prin	crpai wate	r-oearin	j strata.
Type of perforator used Mills Blade	MATERIAL	From	То	swL
Size of perforations 7/16 in. by 2 3/4 in.	Top Soil	0	1	
270perforations from60ft. to85ft.	Yellow Clay	1 1	44	_
90 perforations from 100 ft. to 111 ft.	Brown send and gravel	44	49	
perforations fromft. toft.	Blue Clay	49	60	
(7) SCREENS: Well screen installed? ☐ Yes ☑ No	Brown sand and gravel	60	85	
Manufacturer's Name	Blue Clay		100	
Type Model No	Cemented gravel	100 1	12	
Diam. Slot size Set from ft. to ft.				
Diam Slot size Set from ft. to ft.				
(0) WINT I PROGRES. Drowdown is amount restor level in				
(8) WELL TESTS: Drawdown is amount water level is lowered below static level				
Was a pump test made? ☑ Yes ☐ No If yes, by whom? DRILLER				
Yield: 300 gal./min. with 21 ft. drawdown after 7 hrs.				
400 " 28 " satīle "				
500 " 38 " same "				
Bailer test gal./min. with ft. drawdown after hrs.				
			-	
Temperature of water Depth artesian flow encountered ft.	Work started Oct. 22, 1975 Complete	ed Mov.	5, 75	19
(v) CONSTRUCTION:	Date well drilling machine moved off of well	Nov. 5	75	19
Well seal—Material used Cement	Drilling Machine Operator's Certification:			
Well sealed from land surface toft.	This well was constructed under my Materials used and information reported	direct	superv	ision.
Diameter of well bore to bottom of seal14 in.	best knowledge and belief.	above a	re true	ю шу
Diameter of well bore below seal10 in.	[Signed] Borrold W. morton	Date1.	-6-75	19
Number of sacks of cement used in well seal 11 sacks	(Drilling Machine Operator)		·	
Number of sacks of bentonite used in well seal sacks	Drilling Machine Operator's License No.	٠٠٠٠		
Brand name of bentonite	Water Well Contractor's Certification:			
Number of pounds of bentonite per 100 gallons	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1			
of water lbs./100 gals.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.			
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft. Did any strata contain unusable water? ☐ Yes ☒ No	Name WILLANETTE DRILLING CO. PANY (Person, firm or corporation) (Type or print)			
	(Person, firm or corporation) (Type or print) Address 1450 Bornick Road NE Salem, Oregon			
Type of water? depth of strata	Address ATEM DIALICA KORO NE SE	item, (-	
Method of sealing strata off	[Signed] Mul O. Du	er)	97303	
Was well gravel packed? ☐ Yes 【X No Size of gravel:	(Water Well Contr			************
Gravel placed from ft. to ft.	Contractor's License No. 2 Date	Nov. 6	<u>, 197</u>	⁵ 19