

MARI... 4366

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

RECEIVED JUN 1 1966

State Well No. 6/2w-22A  
State Permit No. 3587 JEEER

(1) OWNER:

Name RUSSELL H. WILLSON  
Address RT-1 BOX 181 B. BRICKS CRE.

(2) LOCATION OF WELL:

County WARREN Driller's well number  
1/4 Section B T. 6S R. 2W W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well  Deepening  Reconditioning  Abandon   
In abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven  Cable  Jetted  Dug  Bored

(6) CASING INSTALLED:

6" Diam. from 0 ft. to 66 ft. Gage 1702\*  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No

Type of perforator used

Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name  
Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BEHTHINITE  
Depth of seal 35 ft. Was a packer used? YES  
Diameter of well bore to bottom of seal 9.5 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? SANDY depth of strata 60'  
Method of sealing strata off CASO D

(10) WATER LEVELS:

Static level 15' 10" ft. below land surface Date 5-28-66  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " "  
" " " " "  
Bailer test 45 gal./min. with 45 ft. drawdown after 1 hrs.  
Artesian flow g.p.m. Date  
Temperature of water 53° Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 66' ft. Depth of completed well 66' ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>TOPSOIL</u>	<u>0</u>	<u>3</u>
<u>CLAY YELLOW - SILTY</u>	<u>3</u>	<u>40</u>
<u>SAND BROWN</u>	<u>40</u>	<u>49</u>
<u>CONCRETE</u>	<u>49</u>	<u>60</u>
<u>SAND MED. TO COARSE</u>	<u>60</u>	<u>65</u>
<u>GRAVEL SAND 1 1/2"</u>	<u>65</u>	<u>66</u>

Work started 5-28-1966 Completed 5-28-1966

Date well drilling machine moved off of well 5-28-1966

(13) PUMP:

Manufacturer's Name BERNLEY  
Type: SUBMERSIBLE H.P. 2

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. ASNEED & SONS  
(Person, firm or corporation) (Type or print)

Address 3910 SILVERTON RD. SALEM, O.

Drilling Machine Operator's License No. 187

[Signed] A. J. Sealed  
(Water Well Contractor)

Contractor's License No. 6 Date 5-28-1966