

4370
MARION

Appl No G 1997

WATER WELL REPORT

STATE OF OREGON

State Well No. 6/2W-220
State Permit No. _____

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

(1) OWNER:
Name J.W. BURR
Address RT. 2 BOX 462 SALEM ORE

(2) LOCATION OF WELL:
County MARION Owner's number, if any—
NE 1/4 NW 1/4 Section 22 T. 6 R. 2W W.M.
Bearing and distance from section or subdivision corner
195° On S & 80° On W from N 1/4 Cor of Section 22

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
8" Diam. from 0 ft. to 73' ft. Gage 7
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:
Perforated? Yes No
Type of perforator used MILLS TYPE
SIZE of perforations in. by in.
3/16 perforations from 2" ft. to _____ ft.
perforations from _____ ft. to _____ ft.
3/60 perforations from 52' ft. to 66' ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:
Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 4" +
Material used in seal— PUMP COVERED
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off CASED + BACK FILLED

(10) WATER LEVELS:
Static level 18" ft. below land surface Date 4-4-61
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:
[Signed] J.W. Burr Date _____, 19____
(Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? STETTLER SUPPLY
Yield: 350 gal./min. with 50 ft. drawdown after 2 hrs.
" 150 " 12'6" " 1 "
" " " " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 53° Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well 8" inches.
Depth drilled 73' ft. Depth of completed well 73' ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	1
CLAY - BLACK - STICKY	1	2'6"
CLAY BROWN - SANDY	2'6"	40'
CONGLOMERATE 2"	40	41
BLUE CLAY	41	47
CONGLOMERATE 3"	47	52
WATER GRAVEL #2"	52	53
CONGLOMERATE 3"	53	59
WATER GRAVEL 3"	59	61
CONGLOMERATE 2"	61	68
BROWN CLAY	68	69
BLUE CLAY	69	73

Work started 4-1-1961 Completed 4-4-1961

(13) PUMP:
Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME J. A. SHEED + SONS
(Person, firm, or corporation) (Type or print)
Address 2505 BROOKS ST - SALEM, O.
Driller's well number _____
[Signed] J. A. Sheed
(Well Driller)
License No. 6 Date 4-4-1961