

**RECEIVED**  
 MAR 1 1962  
**STATE ENGINEER**  
 SALEM, OREGON

MAR 1 1962

**WATER WELL REPORT**

State Well No. 6/2W-22H

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

**STATE ENGINEER**  
**STATE OF OREGON**  
 SALEM, OREGON

62287

State Permit No. \_\_\_\_\_

**(1) OWNER:**

Name VELMA DOERFLER  
 Address 250 LANCASTER DRIVE N.E.  
SALEM, ORE.

**(2) LOCATION OF WELL:**

County MARION Owner's number, if any—  
 1/4 Section 22 T. 6 R. 2W W.M.  
 Bearing and distance from section or subdivision corner

**(3) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
 If abandonment, describe material and procedure in Item 11.

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
 Irrigation  Test Well  Other

**(5) TYPE OF WELL:**

Rotary  Driven   
 Cable  Jetted   
 Dug  Bored

**(6) CASING INSTALLED:**

Threaded  Welded   
 8" Diam. from 0 ft. to 120 ft. Gage 24"  
 " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
 " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**(7) PERFORATIONS:**

Perforated?  Yes  No

Type of perforator used \_\_\_\_\_  
 SIZE of perforations 3/16 in. by 2" in.  
128 perforations from 60 ft. to 66 ft.  
272 perforations from 96 ft. to 118 ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) SCREENS:**

Well screen installed  Yes  No

Manufacturer's Name \_\_\_\_\_  
 Type \_\_\_\_\_ Model No. \_\_\_\_\_  
 \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
 Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Was a surface seal provided?  Yes  No To what depth? 8" + ft.  
 Material used in seal— PUMP COVERED  
 Did any strata contain unusable water?  Yes  No  
 Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_

**(10) WATER LEVELS:**

Static level 21 ft. below land surface Date 2-23-62  
 Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Log Accepted by:

[Signed] Velma E Doerfler Date 2-27, 1962  
 (Owner)

**(11) WELL TESTS:**

Drawdown is amount water level is lowered below static level. STETTLER SUPPLY

Was a pump test made?  Yes  No If yes, by whom?  
 Yield: 450 gal./min. with 14 ft. drawdown after 1 hrs.  
 " 750 " 19 " 1 "

Bailer test gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
 Artesian flow g.p.m. Date \_\_\_\_\_  
 Temperature of water 55 Was a chemical analysis made?  Yes  No

**(12) WELL LOG:**

Diameter of well 8" inches.

Depth drilled 120 ft. Depth of completed well 120 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOPSOIL	0	2
CLAY YELLOW COLOR	2	20
SANDY	20	56
WATER GRAVEL 2"	56	66
CLAY YELLOW COLOR	66	69
CLAY BLUE - STICKY	69	81
CLAY GRAY COLOR	81	89
CONGLOMERATE 3" W.B.	89	116
WATER GRAVEL 3"	116	117
CONGLOMERATE 3"	117	120

Work started 2-19-1962 Completed 2-23 1962

**(13) PUMP:**

Manufacturer's Name \_\_\_\_\_  
 Type: TURBINE H.P. 10

**Well Driller's Statement:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.A. SNEED & SONS  
 (Person, firm, or corporation) (Type or print)

Address 2910 SILVERTON RD. N.E.  
SALEM, ORE.

Driller's well number \_\_\_\_\_

[Signed] B.F. Sneed  
 (Well Driller)

License No. 6 Date 2-24, 1962