NOTICE TO WATER WELL CONTRACTOR

of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

6/2W-27 L

STATE ENGINEER above this line)

State Permit No. ..

CALL & OBECON	G-44 40
(1) OWNER:	(11) LOCATION OF WELL:
Name Pugh Farms Inc. A. L. Pugh	County Marion Driller's well number 1290
Address Rt. 1 Box 239, Brooks, Oregon	14 14 Section 22 T. 65 R. 2W W.M.
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐	
if abandonment, describe material and procedure in Item 12.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	
Rotary Driven D	(12) WELL LOG: Diameter of well below casing
Cable	Depth drilled 150 ft. Depth of completed well 150 ft.
CASING INSTALLED: Threaded Welded 10 Welded 10 ft. Gage 250 ft. Gage 250	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.
	MATERIAL From To SWL
" Diam. from ft. to ft. Gage	Top Soil 0 2
PERFORATIONS: Perforated? M Yes No.	Yellow Clay 2 45
Type of perforator used Mills	Blue Clay 45 55
	Gray Clay 55 100
Size of perforations 2 in. by 3/8 in. 440 perforations from 100 ft. to 150 ft.	Cemented Gravel 100 150 10
perforations from ft. to ft	
perforations from ft. to ft.	
perforations fromft. toft.	
(7) SCREENS: Well screen installed? ☐ Yes 🙀 No	Washington and the same of the
Manufacturer's Name	
Type Model No Diam Slot size Set from ft. to ft.	
Diam. Slot size Set from ft. to ft.	
(8) WATER LEVEL: Completed well.	
Static level 10 ft. below land surface Date2-27-68	
sian pressure lbs. per square inch Date	
(9) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? ▼ Yes □ No If yes, by whom? driller	
d: 300 gal./min. with 55 ft. drawdown after 4 hrs.	Work started 2-9-68 19 Completed 2-27-68 19
350 " 65 " 4 "	Date well drilling machine moved off of well 2-27-68 19
<u>" 400 " 75 " 4 "</u>	Drilling Machine Operator's Certification:
Bailer test gal./min. with ft. drawdown after hrs.	This well was constructed under my direct supervision. Materials used and information reported above are true to my best
Artesian flow g.p.m. Date	knowledge and belief.
Temperature of water 55 Was a chemical analysis made? Yes No	[Signed] Abrill W. Morton Date 2-27-6819
(10) CONSTRUCTION:	Drilling Machine Operator's License No. 536
Well seal-Material used Cement & Puddle clay	Drilling Machine Operator's License No
Depth of sealft.	Water Well Contractor's Certification:
Diameter of well bore to bottom of seal 14 in.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Were any loose strata cemented off? Yes and No Depth	NAME WILLAMENTE DRILLING COMPANY
Was a drive shoe used? T Yes No	(Person, firm or corporation) (Type or print)
Did any strata contain unusable water? Yes No	Address 7641 35th Ave NE Salem, Oregon
Type of water? depth of strata	α , α , α
Method of sealing strata off	[Signed] Signed
Was well gravel packed? ☐ Yes 🏋 No Size of gravel:	(Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No