

RECEIVED

MAY 11 1965 4390

NOTICE TO WATER WELL CONTRACTOR JULY 9 1965
The original and first copy of this report are to be filed with the STATE ENGINEER
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.
WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 6/2w-23
State Permit No.

(1) OWNER:
Name DAVID V. AMOTH
Address I277 WOODACER DRIVE S.E.
SALEM, OREGON

(2) LOCATION OF WELL:
County MARION Driller's well number I042
1/4 1/4 Section 42 T. 6 S R. 2 W W.M.
Bearing and distance from section or subdivision corner
OF ASA SANDERS D.L.C.

(3) TYPE OF WORK (check):
Well [X] Deepening [] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic [] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []
(5) TYPE OF WELL:
Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:
Threaded [] Welded [X]
8" Diam. from TOP ft. to I25 ft. Gage 250

(7) PERFORATIONS:
Perforated [X] Yes [] No []
Type of perforator used MILLS
Size of perforations 3/8 in. by 2 in.
280 perforations from 90 ft. to I23 ft.

(8) SCREENS:
Well screen installed? [] Yes [X] No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal CEMENT & PUTTLE CLAY
Depth of seal 20 ft. Was a packer used?
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? [] Yes [] No Depth
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 45 ft. below land surface Date 6/26/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [] No If yes, by whom? DRILLER
Yield: I40 gal./min. with 10 ft. drawdown after 6 hrs.
" 250 " 25 " 6 "
" 340 " 45 " 6 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:
Diameter of well below casing
Depth drilled I25 ft. Depth of completed well I25 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include TOP SOIL, BROWN CLAY, BROWN SILTY, GRAY CLAY, BLACK SAND SILTY, BROWN CLAY, BROWN SAND, BROWN SAND & SMALL GRAVEL, BROWN SAND & GRAVEL.

Work started JUNE 17 1965. Completed JUNE 26 1965
Date well drilling machine moved off of well JUNE 26 1965

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO.
Address RT. 2 BOX 276 SALEM, OREGON
Drilling Machine Operator's License No. I51
[Signed] Emil O. Beier
Contractor's License No. 2 Date JUNE 26 1965