## NOTICE TO WATER WELL CONTRACTOR The original and first copy WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date The LNG (Do not write above this line)
of well completion. SALEM, OREGON



State Permit No.

(1) OWNER:	(11) LOCATION OF WELL:	
Name Ed Boies	County Marion Driller's well number 1253	
Address Rt. 1 Box 181, Brooks, Oregon	14 14 Section 14 T6S R. 2W	W.M.
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner	
	,	
New Well <b>K</b> Deepening □ Reconditioning □ Abandon □ If abandonment, describe material and procedure in Item 12.		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	*	—
Rotary C Driven C	(12) WELL LOG: Diameter of well below casing	
Cable  ☐ Jetted ☐ Domestic ☐ Industrial ☐ Municipal ☐ Dug ☐ Bored ☐ Irrigation ☐ Test Well ☐ Other ☐	Depth drilled 110 ft. Depth of completed well 110	ft.
CASING INSTALLED: Threaded Welded M. 10." Diam. from top ft to 110 ft. Gage 250	Formation: Describe color, texture, grain size and structure of mater and show thickness and nature of each stratum and aquifer penetre with at least one entry for each change of formation. Report each chin position of Static Water Level as drilling proceeds. Note drilling r	ated, ange
	MATERIAL From To SV	wL
ft. to ft. Gage	Top Soil 0 1	
PERFORATIONS: Perforated? Yes No.	Brown Clay 1 30	
Type of perforator used Mills	Black sand 30 70	
Size of perforations 2 in. by 3/8 in.	Black sand & Gravel 70 110 15	<u>;</u>
310 perforations from 81 ft. to 109 ft.		
perforations fromft_ toft_		
perforations from ft. toft.		
perforations from ft. to ft.		
perforations from ft. to ft.		
(7) SCREENS: Well screen installed?   Yes No		
Manufacturer's Name		
Type Model No	·	
Diam.       Slot size       Set from       ft. to       ft.         Diam.       Slot size       Set from       ft. to       ft.		
(8) WATER LEVEL: Completed well.		
Static level 15 ft. below land surface Date 8/24/67		
sian pressure lbs. per square inch Date		
(9) WELL TESTS: Drawdown is amount water level is lowered below static level		
Was a pump test made?  Yes □ No If yes, by whom? driller	Work started 8/7/67 19 Completed 8/25/57 19	
d: 450 gal./min. with 65 ft. drawdown after 8 hrs.	Date well drilling machine moved off of well 8/24/67	
" " "	Drilling Machine Operator's Certification:	-:
Bailer test gal./min. with ft. drawdown after hrs.	This well was constructed under my direct supervision. M	ate-
Artesian flow g.p.m. Date	rials used and information reported above are true to my knowledge and belief.	best
Temperature of water 55 Was a chemical analysis made? ☐ Yes 🙀 No	[Signed] A Mechanic Operator) Date 8/25/6,719	) <u></u> .
(10) CONSTRUCTION:	Drilling Machine Operator's License No151	
Well seal-Material used Cement & Puddle clay	Drilling Machine Operator's License No	
Depth of sealft.	Water Well Contractor's Certification:	
Diameter of well bore to bottom of seal 14 in.	This well was drilled under my jurisdiction and this report true to the best of my knowledge and belief.	rt is
Were any loose strata cemented off?   Yes   No Depth	NAME WILLAMETTE DRILLING COMPANY	
Was a drive shoe used? ▼ Yes □ No	(Person, firm or corporation) (Type or print)	
Did any strata contain unusable water?   Yes X No	Address Rt. 2 Box 276, Salem, Oregon	
Type of water? depth of strata	0.000	
Method of sealing strata off	[Signed] My Delly	
Was well gravel packed? ☐ Yes ☑ No Size of gravel:	(Water Well Contractor)	
Gravel placed from ft to ft	Contractor's License No. 2 Date 8/25/67 19	