

NOTICE TO WATER WELL CONTRACTOR  
The original and final copy  
of this report are to be  
filed with the

**RECEIVED**  
JUL 20 1971

**WATER WELL REPORT**

4435  
MAR 11 1971  
6/2W-25  
66976

STATE OF OREGON  
State Well No. 6/2W-25

STATE ENGINEER, SALEM, OREGON (Please type or print)  
within 30 days from the date of well completion  
SALEM OREGON (Do not write above this line)  
Phone call 3-24-72 RI

**(1) OWNER:**

Name ROUBEN DITCHER  
Address R.F.D. 2 SILVERTON OREG

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

**(4) PROPOSED USE (check):**

Rotary  Driven   
Cable  Jetted   
Dug  Bored   
Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**CASING INSTALLED:**

12" Diam. from 61 ft. to 225 ft. Gage 250  
" Diam. from ..... ft. to ..... ft. Gage .....  
" Diam. from ..... ft. to ..... ft. Gage .....

**PERFORATIONS:**

Type of perforator used Drills  
Size of perforations 5 in. by 2 in.  
~~8 1/2~~ perforations from 143 ft. to 197 ft.  
~~2 1/2~~ perforations from ..... ft. to ..... ft.  
15 7/8 perforations from 143 ft. to 219 ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
Manufacturer's Name ..... Model No. ....  
Type ..... Slot size ..... Set from ..... ft. to ..... ft.  
Diam. ..... Slot size ..... Set from ..... ft. to ..... ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No. If yes, by whom? WELLS  
Yield: 500 gal./min. with 30 ft. drawdown after 4 hrs.  
" " " " " "  
" " " " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m.  
Temperature of water Depth artesian flow encountered ft.

**(9) CONSTRUCTION:**

Well seal—Material used DRILLING CLAY  
Well sealed from land surface to 40 ft.  
Diameter of well bore to bottom of seal 16 in.  
Diameter of well bore below seal 12 in.  
Number of sacks of cement used in well seal ..... sacks  
Number of sacks of bentonite used in well seal ..... sacks  
Brand name of bentonite .....  
Number of pounds of bentonite per 100 gallons of water ..... lbs./100 gals.  
Was a drive shoe used?  Yes  No. Plugs ..... Size: location ..... ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? ..... depth of strata .....  
Method of sealing strata off .....  
Was well gravel packed?  Yes  No. Size of gravel: .....  
Gravel placed from ..... ft. to ..... ft.

**(10) LOCATION OF WELL:**

County MARION Driller's well number .....  
1/4 Section 25 T. 6, S R. 2, W W.M.  
Bearing and distance from section or subdivision corner

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 50 ft.  
Static level 55 ft. below land surface. Date 6-23-71  
Artesian pressure lbs. per square inch. Date

**(12) WELL LOG:**

Diameter of well below casing 12  
Depth drilled 225 ft. Depth of completed well 225 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil	0	4	
BROWN - CLAY	4	17	
" - " SANDY	17	30	
BLUE - CLAY	30	85	
BROWN - SAND	85	106	
" - " GRAVEL	106	118	
" - CRAMMENTED GRAVEL	118	143	
MED. " "	143	177	
BROWN - CRAMMENTED GRAVEL	177	198	
MED. SAND & GRAVEL	198	219	
BLUE - CLAY	219	225	

Work started 5-26-1971 Completed 6-23-1971  
Date well drilling machine moved off of well 6-24-1971

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] William West of Charles Miller Date 6-24-1971  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 158

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Charles Miller & West (Type or print)  
Address 5545 Jackson St. S.E. Salem  
[Signed] Charles Miller (Water Well Contractor)  
Contractor's License No. 37 Date 6-24-1971