

4441
MARION

WATER WELL REPORT
STATE OF OREGON G-6146

State Well No. 6/2W-25Q(1)
State Permit No. _____

(1) OWNER:

Name JENSON BROS.
Address RTE. 2
SILVERTON, OREGON

(2) LOCATION OF WELL:

County MARION Owner's number, if any—
1/4 Section T. R. W.M.
Bearing and distance from section or subdivision corner
650 ft. east & 350 ft. north from S.W. cor
of D.L.C. 45, T. 6 S., R. 2 W. of W.M.

SW cor of D.L.C. 45 is S 71° 12' W - 5.50 chains from S 1/4 corner 25
(falling in Sec 36)

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
10" Diam. from 0 ft. to 181 ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used _____
SIZE of perforations 7/8 in. by 3 in.
1200 perforations from 80 ft. to 180 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 20 ft.
Material used in seal— BENTONITE
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 36 ft. below land surface Date 6/2/62
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by: _____

Signed] _____ Date _____, 19____
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? DRILLER
Yield: 500 gal./min. with 61 ft. drawdown after 8 hrs.
" " " " " "
" " " " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water X Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 10 inches.
Depth drilled 195 ft. Depth of completed well 195 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL BROWN	0	3
CLAY BR	3	25
CLAY BLUE	25	45
CLAY BR	45	60
CLAY GREY	60	79
MED CONG: GREY W.B	79	81
LOOSE GRAVEL WB	81	90
MED CONG W.B	90	95
COURSE GRAVEL WB	95	100
MED CONG WR	100	103
LOOSE GRAVEL WR	103	107
HARD CONG	107	124
SOFT CONG	124	133
LOOSE GRAVEL WB	133	136
CLAY SOME GRAVEL GREY	136	138
MED CONG WB	138	149
LOOSE SAND & GRAVEL BROWN	149	152
MED CONG	152	174
LOOSE SAND & GRAVEL BROWN	174	177
MED CONG BROWN	177	181
CLAY GREY	181	195
HIT GREY CLAYSTONE		
AT	195	

Work started 5/18 1962 Completed 6/4 1962

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. STADELI & SONS
(Person, firm, or corporation) (Type or print)

Address RT 3 BOX 169 SILVERTON

Driller's well number _____

[Signed] C.E. Stadel
(Well Driller)

License No. 296 Date 6/30, 1963