

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97331
within 30 days from the date
of well completion.

WATER WELL REPORT

RECEIVED

STATE OF OREGON
(Please type or print)

MAR 4442

State Well No. 65/2w-26
State Permit No.

APR 10 1979 (Do not write above this line)

(1) OWNER: WATER RESOURCES DEPT.
SALEM, OREGON

Name E. Alan Haslebacher
Address 6891 80th Ave. NE
Salem, Oregon 97303

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

10" Diam. from top ft. to 305 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used Mills Knife
Size of perforations 3/8 in. by 2 3/4 in.
1180 perforations from 105 ft. to 210 ft.
110 perforations from 225 ft. to 235 ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom driller
Yield: 700 gal./min. with 13 ft. drawdown after 4 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Portland Cement
Well sealed from land surface to 19 ft.
Diameter of well bore to bottom of seal 14 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 11 sacks
How was cement grout placed? placed through "tremy" pipe

Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number 2199
1/4 1/4 Section 26 T. 6S R. 2W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 85 ft.
Static level 40 ft. below land surface. Date 3/8/79
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 10

Depth drilled 350 ft. Depth of completed well 305 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	1	
Yellow Clay	1	25	
Blue Clay	25	75	
Yellow Clay	75	85	
Brown Sand	85	93	
Cemented Brown Sand and Gravel	93	215	
Blue Clay	215	222	
Cemented Black Sand and Gravel	222	235	
Blue Clay	235	253	
Black Sand	253	264	
Blue Clay	264	310	
Brown Clay	310	350	

Work started 1/15/79 19 Completed 3/8/79 19
Date well drilling machine moved off of well 3/8/79 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] *Bernard W. Moxton* Date 3/8/79, 19...
(Drilling Machine Operator)

Drilling Machine Operator's License No. 536

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Willamette Drilling Co.
(Person, firm or corporation) (Type or print)

Address 7365 O'Neill Rd. NE Salem, Oregon 97303

[Signed] *Dallas J. Dewey*
(Water Well Contractor)

Contractor's License No. 561 Date 3/8/79, 19...