

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

STATE OF OREGON
(Please type or print)

State Well No. 6/2W-26
State Permit No. _____

MAR 9 1964

(1) OWNER: Allan Haslebacher
Name Ed Haslebacher
Address Rt. 2, Box 493 Salem, Oreg.

(2) LOCATION OF WELL:
County Marion Driller's well number _____
Bearing and distance from section or subdivision corner
2375 ft. E. and 1600 ft. N. of S.W. cor. of sec. 26, T.6 S., R.2 W. of W.M.

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
Threaded Welded
" Diam. from 0 ft. to 185 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:
Type of perforator used mills Perforated? Yes No
Size of perforations 4 in. by 4 in.
67 perforations from 100 ft. to 184 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:
Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Bentonite
Depth of seal 20 ft. Was a packer used? no
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 42 ft. below land surface Date 10/9/64
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Yield: 450 gal./min. with 68 ft. drawdown after 6 hrs.
" " " " " "
" " " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing none
Depth drilled 185 ft. Depth of completed well 185 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil brown	1	3
Clay brn.	3	8
Clay sandy grey	8	70
Sand fine brn.	70	95
Med conglomerate grey W.B.	95	118
Loose sand & gravel grey W.B.	118	125
Med conglom brn. W.B.	125	185
Bottomed on hard basalt blk.		

Work started 9/15 1964. Completed 10/9 1964
Date well drilling machine moved off of well 10/9 1964

(13) PUMP:
Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME R. Stadel & Sons.
(Person, firm or corporation) (Type or print)
Address Rt. 3 Box 169 Silverton, Oreg.
Drilling Machine Operator's License No. 84
[Signed] Paul R. Stadel
(Water Well Contractor)
Contractor's License No. 296 Date 10/14, 1964