

RECEIVED
MAR 27 1959

MARI 4446

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER WATER WELL REPORT STATE OF OREGON

State Well No. 6/2W-26E(1)
App State Permit No. G-1245

(1) OWNER:

Name Albert Haslebacher
Address Rt. 2 Box 484
Salem, Oregon

(2) LOCATION OF WELL:

County Marion Owner's number, if any—
SW 1/4 NW 1/4 Section 26 T. 6 S. R. 2 W. W.M.
Bearing and distance from section or subdivision corner

App. Permit # G-1245

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

10" Diam. from Top ft. to 173 ft. Gage 31.20#
Threaded Welded
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Mills
SIZE of perforations 5/16 in. by 1 1/2 in.
860 perforations from ft. to ft.
94 perforations from ft. to 172 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? 15 ft.
Material used in seal— Puddled clay
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 48 ft. below land surface Date 3-16-59
Artesian pressure lbs. per square inch Date

Log Accepted by:

A. J. Haslebacher
[Signed] Date 3-16-59, 1959
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? - Sears
Yield: gal./min. with ft. drawdown after hrs.
" Pump Test Below " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 57 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 10 inches.
Depth drilled 173 ft. Depth of completed well 173 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	3
Yellow clay	3	15
Yellow sand & silt	15	32
Sandy blue soft clay	32	62
Hard sticky blue clay	62	80
Sandy gray clay	80	92
Black Sand & Gravel	92	95
Thin layers of sand & gravel between layers of clay & gravel (Hard & tight)	95	145
Loose sand & gravel	145	150
Hard sand & gravel & clay	150	151
Loose Sand & Gravel	151	156
Thin layers of sand & gravel between layers of hard clay	156	167
Loose sand & gravel	167	173

Pump Test

675	GPM	@	122 ft.
600	GPM	@	115 ft.
500	GPM	@	104 ft.
400	GPM	@	92 ft.
370	GPM	@	90 ft.
350	GPM	@	86 ft.
270	GPM	@	81 ft.

Work started 11-20-58 19 Completed 3-16-59 19

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Irving Sears
(Person, firm, or corporation) (Type or print)

Address Rt. 1 Gervais, Oregon

Driller's well number 465

[Signed] Irving Sears
(Well Driller)

License No. 8 Date 3-16-59, 19