

Received 10/16/61

MAR 4 449

6/2W-26

WATER WELL REPORT

State Well No.

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE OF OREGON

State Permit No.

(1) OWNER:
 Name Harold J. Austin
 Address Route 2 Box 490
Salem Oregon

(2) LOCATION OF WELL:
 County Marion Owner's number, if any—
SE 1/4 SW 1/4 Section 26 T. 6S R. 2W W.M.
 Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
 New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check): **(5) TYPE OF WELL:**
 Domestic Industrial Municipal Rotary Driven
 Irrigation Test Well Other Cable Jetted
 Dug Bored

(6) CASING INSTALLED: Threaded Welded
10" Diam. from 0 ft. to 190'0" ft. Gage 216
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? Yes No
 Type of perforator used Drive down
 SIZE of perforations 28 in. by 128 in.
300 perforations from 110 ft. to 130 ft.
300 perforations from 130 ft. to 150 ft.
300 perforations from 150 ft. to 170 ft.
300 perforations from 170 ft. to 190 ft.
 perforations from ft. to ft.

(8) SCREENS: Well screen installed Yes No
 Manufacturer's Name
 Type Model No.
 Dia. Slot size Set from ft. to ft.
 Slot size Set from ft. to ft.

(9) CONSTRUCTION:
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from ft. to ft.
 Was a surface seal provided? Yes No To what depth? ft.
 Material used in seal— GRUNT
 Did any strata contain unusable water? Yes No
 Type of water? Depth of strata
 Method of sealing strata off

(10) WATER LEVELS:
 Static level 38 ft. below land surface Date Sept 12
 Artesian pressure lbs. per square inch Date

Log Accepted by: Harold J. Austin
 [Signed] Date, 19.....
 (Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level BECKER'S TRACTOR
 Was a pump test made? Yes No If yes, by whom? TRACTOR
 Yield: 700 gal./min. with 47 ft. drawdown after 4 hrs.
 " " " " " "
 " " " " " "
 " " " " " "
 Bailer test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m. Date
 Temperature of water 52 Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well 10 inches.
 Depth drilled 190 ft. Depth of completed well 190 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
BROWN SILT	0	35
BLUE CLAY	35	55
LIGHT BROWN CLAY	55	70
SANDY CLAY NOW	70	88
GRAVEL	88	95
BLUE CLAY	95	103
CEMENTED GRAVEL	103	125
COURSE SAND	125	132
LOOSE SAND AND GRAVEL	132	140
CEMENTED GRAVEL	140	160
LOOSE GRAVEL	160	175
SAND WITH WATER	175	190

Work started Sept 12 1961 / Completed Oct 6 1961

(13) PUMP:
 Manufacturer's Name
 Type: H.P.

Well Driller's Statement:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLIAM J. STENNETT
 (Person, firm, or corporation) (Type or print)
 Address 361 WARNER MILNE RD ORE CITY
 Driller's well number
 [Signed] William J. Stennett
 (Well Driller)
 License No. 5 Date Oct 15, 1961

PUMPS SERVICE S. LVERTON