

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

DATE OF OREGON

Please type or print)

(Do not write above this line)

STATE ENGINEER

SALEM, OREGON

RECEIVED JUL 20 1970

4459 MAR 1970

State Well No.

State Permit No.

abb 6/2W-27

G5264

(1) OWNER:

Name Leslie Klampe Address 6796 Labish Center Road NE Salem, Ore.

(2) TYPE OF WORK (check):

New Well [x] Deepening [ ] Reconditioning [ ] Abandon [ ]

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [x] Jetted [ ] Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [x] Test Well [ ] Other [ ]

CASING INSTALLED:

10" Diam. from top ft. to 170 ft. Gage 250

PERFORATIONS:

Perforated? [x] Yes [ ] No.

Type of perforator used Mills Size of perforations 2 in. by 3/8 in. 160 perforations from 65 ft. to 80 ft. 650 perforations from 110 ft. to 168 ft.

(7) SCREENS:

Well screen installed? [ ] Yes [x] No

Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 32 ft. below land surface Date 7-6-70

Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [x] Yes [ ] No If yes, by whom? Driller Yield: 270 gal./min. with 25 ft. drawdown after 4 1/2 hrs. 350 " 36 " 4 1/2 " 400 " 41 " 4 1/2 "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? [ ] Yes [ ] No

(10) CONSTRUCTION:

Well seal—Material used Cement and Puddle Clay

Depth of seal 20 ft.

Diameter of well bore to bottom of seal 12 in.

Were any loose strata cemented off? [ ] Yes [ ] No Depth

Was a drive shoe used? [x] Yes [ ] No

Did any strata contain unusable water? [ ] Yes [ ] No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? [ ] Yes [x] No Size of gravel:

Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Marion Driller's well number 1495 NW 1/4 NW 1/4 Section 27 T. 6S R. 2W W.M. Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing

Depth drilled 170 ft. Depth of completed well 170 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include Top Soil, Yellow Clay, Blue Clay, Brown sand, Brown sand and gravel, Blue clay, Cemented Gravel.

Work started June 16, 1970 Completed July 7, 1970

Date well drilling machine moved off of well July 7, 1970

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Ronald Norton (Drilling Machine Operator) Date 7-7-70, 1970

Drilling Machine Operator's License No. 536

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING COMPANY (Person, firm or corporation) (Type or print)

Address 7641 35th Ave. NE Salem, Oregon 97303

[Signed] Emil O. Beier (Water Well Contractor)

Contractor's License No. 2 Date 7-7-70, 1970