

4460
MAY 11 1969

NOTICE TO WATER WELL CONTRACTOR

The original and true copy of this report are to be filed with

RECEIVED
NOV 21 1969

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Well No. 6/2W-27dc

State Permit No. G-6301

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

STATE ENGINEER
SALEM, OREGON

(1) OWNER:

Name Raymond A. Haslebacher
Address 7292 74th N.E. Salem

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

12 3/4" Diam. from 0+2 ft. to 147 ft. Gage .250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used Mills Knife
Size of perforations 2 in. by 3/8 in.
1308 perforations from 91 ft. to 145 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Type _____ Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 48 1/2 ft. below land surface Date 11/11/69
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Stettler
Flow: 640 gal./min. with 52 ft. drawdown after 3 hrs.
" 700 " " 55 " " 1/4 "
" 900 " " 69 " " 1/4 "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Bentonite
Depth of seal 30 ft.
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County Macon Driller's well number _____
N 1/4 SE 1/4 Section 27 T. 65 R. 200 W.M.
Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 12

Depth drilled 149 ft. Depth of completed well 148 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Soil	0	1	
Clay (Brown)	1	63	
Clay & Sand	63	79	
Cemented Gravel (Brown)	79	82	
Sand & clay	82	83	
Clean gravel (Brown)	83	85	
Gravel (Some clay)	85	91	
Gravel (Clean & loose)	91	120	
Gravel & clay (Brown)	120	122	
Gravel (Clean)	122	132	
Gravel & some clay binder	132	134	
Gravel (tight)	134	149	

Work started 10/22 1969 Completed 11/12 1969

Date well drilling machine moved off of well 11/13 1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] George H. Robinson Date 11/13, 1969
(Drilling Machine Operator)

Drilling Machine Operator's License No. 64

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME George Robinson Drilling
(Person, firm or corporation) (Type or print)

Address 1734 82nd St S.E.

[Signed] George H. Robinson
(Water Well Contractor)

Contractor's License No. 13 Date 11/13, 1969