

RECEIVED

MARION 4464

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON, within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 6/2w-27
State Permit No.

(1) OWNER:

Name JESS R. DECAIR
Address RT. 2 BOX 445 SALEM, OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number 897
1/4 1/4 Section 27 T. 6S R. 2W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

Threaded [] Welded [X]
8" Diam. from TOP 90 ft. to 250 ft. Gage

(7) PERFORATIONS:

Perforated? [X] Yes [] No
Type of perforator used Mills
Size of perforations 3/8 in. by 5 in.
152 perforations from 53 ft. to 70 ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUDDLE CLAY
Depth of seal 20 ft. Was a packer used?
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? [] Yes [] No Depth
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 20 ft. below land surface Date FEB. 24
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [] No If yes, by whom? DRILLER
Yield: 400 gal./min. with 30 ft. drawdown after 12 hrs.
325 " 15 " 12 "
250 " 15 " 12 "

(12) WELL LOG:

Diameter of well below casing
Depth drilled 90 ft. Depth of completed well 90 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO. Rows include TOP SOIL, CLAY, SAND, GRAVEL, SAND, GRAVEL.

BALANCE OF PUMP TEST

200 GAL WITH 10 FT DRAWDOWN
175 GAL WITH 7 FT. DRAWDOWN

Work started FEB 17 1964 Completed FEB 24 1964
Date well drilling machine moved off of well FEB 24 1964

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO
Address RT. 2 BOX 276 SALEM, OREGON

Drilling Machine Operator's License No. 179
[Signed] Emil O. Beier
Contractor's License No. 2 Date FEB 25 1964