

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER WELL REPORT

RECEIVED

65/20-28ca

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
(Please type or print)

MAY 20 1981 State Well No.

WATER RESOURCES DEPT
SALEM, OREGON Dept. No.

(Do not write above this line)

(1) OWNER:

Name Van Cleave Farms
Address 6586 55th Ave. N.E.
Salem, Oregon 97303

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
6" Diam. from +1 ft. to 120 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used Torch
Size of perforations 1/2 in. by 4 in.
30 perforations from 113 ft. to 120 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Arttest 100+ GPM for a period of 1 hour "
" " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement and 5% bentonite
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 5 sacks
How was cement grout placed? pumped in through conductor pipe

Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number 2362
NE 1/4 SW 1/4 Section 28 T. 6S R. 2W W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 68 ft.
Static level 43 ft. below land surface. Date 5/2/81
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing
Depth drilled 120 ft. Depth of completed well 120 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
<u>X Topsoil</u>	<u>0</u>	<u>2</u>	
<u>Brown Clay</u>	<u>2</u>	<u>68</u>	
<u>Brown Sand</u>	<u>68</u>	<u>73</u>	
XXXXXX			
<u>Cemented Brown Sand and Gravel</u>	<u>73</u>	<u>109</u>	
<u>Brown Sand and Gravel</u>	<u>109</u>	<u>120</u>	

Work started 5/2/81 19 81 Completed 5/2/81 19

Date well drilling machine moved off of well 5/2/81 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Dallas L Davis Date 5/2/81, 19____
(Drilling Machine Operator)

Drilling Machine Operator's License No. 752

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Willamette Drilling Co.
(Person, firm or corporation) (Type or print)

Address 7365 O'Neil Rd. N.E. Salem, Oregon 9730

[Signed] Dallas L Davis
(Water Well Contractor)

Contractor's License No. 561 Date 5/2/81, 19____